

trạm nước thải giấy Bắc Hà

Time	pH	TSS	TSS	NH4+	NH4+	COD	COD	Temp	Temp	Flow	Flow	ir	Flow	c	Flow	out	
	Value	Value	Unit	Value	Unit	Value	Unit	Value	Unit	Value	Unit	Value	Unit	Value	Unit	Value	Unit
01:05:00 12/12/2025	7.9	10.7	mg/L	0.01	mg/L	23.1	mg/L	22.5	oC	25.1	m3/h		0	m3/h			
01:10:00 12/12/2025	7.9	10.7	mg/L	0.02	mg/L	23.1	mg/L	22.6	oC	29.1	m3/h		0	m3/h			
01:15:00 12/12/2025	7.9	10.7	mg/L	0.02	mg/L	23	mg/L	22.6	oC	28.3	m3/h		0	m3/h			
01:20:00 12/12/2025	7.9	10.5	mg/L	0.03	mg/L	23	mg/L	22.6	oC	27.7	m3/h		0	m3/h			
01:25:00 12/12/2025	7.9	10.6	mg/L	0.02	mg/L	23.1	mg/L	22.6	oC	27	m3/h		0	m3/h			
01:30:00 12/12/2025	7.9	10.6	mg/L	0.03	mg/L	23	mg/L	22.6	oC	25.7	m3/h		0	m3/h			
01:35:00 12/12/2025	7.9	10.7	mg/L	0.02	mg/L	23	mg/L	22.6	oC	25.8	m3/h		0	m3/h			
01:40:00 12/12/2025	7.9	10.7	mg/L	0.01	mg/L	23.1	mg/L	22.5	oC	27.2	m3/h		0	m3/h			
01:45:00 12/12/2025	7.9	10.6	mg/L	0.02	mg/L	23	mg/L	22.6	oC	26.1	m3/h		0	m3/h			
01:50:00 12/12/2025	7.9	10.7	mg/L	0.02	mg/L	23	mg/L	22.5	oC	26.1	m3/h		0	m3/h			
01:55:00 12/12/2025	7.9	10.7	mg/L	0.02	mg/L	23.1	mg/L	22.6	oC	28.3	m3/h		0	m3/h			
02:00:00 12/12/2025	7.9	10.7	mg/L	0.02	mg/L	23	mg/L	22.6	oC	0	m3/h		0	m3/h			
02:05:00 12/12/2025	7.9	10.5	mg/L	0.02	mg/L	23.1	mg/L	22.5	oC	0	m3/h		0	m3/h			
02:10:00 12/12/2025	7.9	10.5	mg/L	0.02	mg/L	23.1	mg/L	22.5	oC	0	m3/h		0	m3/h			
02:15:00 12/12/2025	7.9	10.7	mg/L	0.03	mg/L	23	mg/L	22.5	oC	0	m3/h		0	m3/h			
02:20:00 12/12/2025	7.9	10.7	mg/L	0.02	mg/L	22.9	mg/L	22.6	oC	0	m3/h		0	m3/h			
02:25:00 12/12/2025	7.9	10.8	mg/L	0.01	mg/L	22.9	mg/L	22.6	oC	0	m3/h		0	m3/h			
02:30:00 12/12/2025	7.9	10.6	mg/L	0.03	mg/L	22.9	mg/L	22.6	oC	0	m3/h		0	m3/h			
02:35:00 12/12/2025	7.9	10.7	mg/L	0.02	mg/L	23	mg/L	22.5	oC	0	m3/h		0	m3/h			
02:40:00 12/12/2025	7.9	10.7	mg/L	0.02	mg/L	22.9	mg/L	22.6	oC	0	m3/h		0	m3/h			
02:45:00 12/12/2025	7.9	10.8	mg/L	0.02	mg/L	22.9	mg/L	22.5	oC	0	m3/h		0	m3/h			
02:50:00 12/12/2025	7.9	10.8	mg/L	0.01	mg/L	22.9	mg/L	22.5	oC	0	m3/h		0	m3/h			
02:55:00 12/12/2025	7.9	10.6	mg/L	0.02	mg/L	22.9	mg/L	22.6	oC	0	m3/h		0	m3/h			
03:00:00 12/12/2025	7.9	10.8	mg/L	0.02	mg/L	22.9	mg/L	22.6	oC	27.3	m3/h		0	m3/h			
03:05:00 12/12/2025	7.9	10.6	mg/L	0.02	mg/L	22.8	mg/L	22.6	oC	32.6	m3/h		0	m3/h			
03:10:00 12/12/2025	7.9	10.5	mg/L	0.01	mg/L	22.8	mg/L	22.6	oC	32.1	m3/h		0	m3/h			
03:15:00 12/12/2025	7.9	10.8	mg/L	0.01	mg/L	22.8	mg/L	22.6	oC	31.6	m3/h		0	m3/h			
03:20:00 12/12/2025	7.9	10.6	mg/L	0.02	mg/L	22.8	mg/L	22.5	oC	31.3	m3/h		0	m3/h			
03:25:00 12/12/2025	7.9	10.6	mg/L	0.01	mg/L	22.6	mg/L	22.6	oC	30.6	m3/h		0	m3/h			
03:30:00 12/12/2025	7.9	10.5	mg/L	0.03	mg/L	22.6	mg/L	22.6	oC	31	m3/h		0	m3/h			
03:35:00 12/12/2025	7.9	10.7	mg/L	0.02	mg/L	22.6	mg/L	22.5	oC	30.7	m3/h		0	m3/h			
03:40:00 12/12/2025	7.9	10.6	mg/L	0.02	mg/L	22.5	mg/L	22.6	oC	30.5	m3/h		0	m3/h			
03:45:00 12/12/2025	7.9	10.8	mg/L	0.02	mg/L	22.8	mg/L	22.5	oC	32.7	m3/h		0	m3/h			
03:50:00 12/12/2025	7.9	10.7	mg/L	0.02	mg/L	22.8	mg/L	22.6	oC	32.3	m3/h		0	m3/h			
03:55:00 12/12/2025	7.9	10.8	mg/L	0.02	mg/L	22.8	mg/L	22.5	oC	31.2	m3/h		0	m3/h			
04:00:00 12/12/2025	7.9	10.7	mg/L	0.02	mg/L	22.8	mg/L	22.6	oC	31.2	m3/h		0	m3/h			
04:05:00 12/12/2025	7.9	10.8	mg/L	0.02	mg/L	22.6	mg/L	22.5	oC	32.1	m3/h		0	m3/h			
04:10:00 12/12/2025	7.9	10.8	mg/L	0.03	mg/L	22.5	mg/L	22.4	oC	32.7	m3/h		0	m3/h			
04:15:00 12/12/2025	7.9	10.6	mg/L	0.02	mg/L	22.4	mg/L	22.5	oC	30.3	m3/h		0	m3/h			
04:20:00 12/12/2025	7.9	10.7	mg/L	0.01	mg/L	22.4	mg/L	22.5	oC	28.2	m3/h		0	m3/h			

04:25:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	22.5 mg/L	22.4 oC	27.9 m3/h	0 m3/h
04:30:00	12/12/2025	7.9	11 mg/L	0.02 mg/L	22.4 mg/L	22.4 oC	26.9 m3/h	0 m3/h
04:35:00	12/12/2025	7.9	10.9 mg/L	0.03 mg/L	22.4 mg/L	22.4 oC	29.5 m3/h	0 m3/h
04:40:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	22.3 mg/L	22.5 oC	29 m3/h	0 m3/h
04:45:00	12/12/2025	7.8	10.7 mg/L	0.02 mg/L	22.3 mg/L	22.5 oC	27 m3/h	0 m3/h
04:50:00	12/12/2025	7.9	10.7 mg/L	0.03 mg/L	22.3 mg/L	22.4 oC	26.6 m3/h	0 m3/h
04:55:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	22.5 mg/L	22.4 oC	25.5 m3/h	0 m3/h
05:00:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	22.6 mg/L	22.4 oC	28.2 m3/h	0 m3/h
05:05:00	12/12/2025	7.9	10.8 mg/L	0.02 mg/L	22.4 mg/L	22.5 oC	26.9 m3/h	0 m3/h
05:10:00	12/12/2025	7.9	10.5 mg/L	0.02 mg/L	22.1 mg/L	22.5 oC	28.4 m3/h	0 m3/h
05:15:00	12/12/2025	7.9	10.8 mg/L	0.01 mg/L	22.3 mg/L	22.5 oC	28.3 m3/h	0 m3/h
05:20:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	22.1 mg/L	22.4 oC	27.2 m3/h	0 m3/h
05:25:00	12/12/2025	7.9	10.8 mg/L	0.01 mg/L	22.1 mg/L	22.4 oC	27.5 m3/h	0 m3/h
05:30:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	22 mg/L	22.4 oC	27 m3/h	0 m3/h
05:35:00	12/12/2025	7.9	10.8 mg/L	0.03 mg/L	21.9 mg/L	22.4 oC	26.9 m3/h	0 m3/h
05:40:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	21.9 mg/L	22.5 oC	25.6 m3/h	0 m3/h
05:45:00	12/12/2025	7.9	10.8 mg/L	0.02 mg/L	21.9 mg/L	22.4 oC	26.6 m3/h	0 m3/h
05:50:00	12/12/2025	7.9	10.8 mg/L	0.02 mg/L	21.9 mg/L	22.4 oC	27.2 m3/h	0 m3/h
05:55:00	12/12/2025	7.9	10.6 mg/L	0.02 mg/L	21.9 mg/L	22.5 oC	26.9 m3/h	0 m3/h
06:00:00	12/12/2025	7.9	10.6 mg/L	0.02 mg/L	22.1 mg/L	22.4 oC	25.6 m3/h	0 m3/h
06:05:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	21.9 mg/L	22.5 oC	26.1 m3/h	0 m3/h
06:10:00	12/12/2025	7.9	10.6 mg/L	0.02 mg/L	21.9 mg/L	22.4 oC	27 m3/h	0 m3/h
06:15:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	21.9 mg/L	22.4 oC	26.9 m3/h	0 m3/h
06:20:00	12/12/2025	7.9	10.5 mg/L	0.03 mg/L	21.8 mg/L	22.4 oC	26.9 m3/h	0 m3/h
06:25:00	12/12/2025	7.9	10.8 mg/L	0.03 mg/L	21.9 mg/L	22.4 oC	26.3 m3/h	0 m3/h
06:30:00	12/12/2025	7.9	10.7 mg/L	0.01 mg/L	21.6 mg/L	22.4 oC	26.1 m3/h	0 m3/h
06:35:00	12/12/2025	7.9	10.8 mg/L	0.01 mg/L	21.6 mg/L	22.4 oC	26 m3/h	0 m3/h
06:40:00	12/12/2025	7.9	10.7 mg/L	0.01 mg/L	21.6 mg/L	22.4 oC	27.3 m3/h	0 m3/h
06:45:00	12/12/2025	7.9	10.7 mg/L	0.03 mg/L	21.6 mg/L	22.3 oC	29 m3/h	0 m3/h
06:50:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	21.8 mg/L	22.4 oC	26.5 m3/h	0 m3/h
06:55:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	21.5 mg/L	22.4 oC	27.2 m3/h	0 m3/h
07:00:00	12/12/2025	7.9	10.8 mg/L	0.02 mg/L	21.8 mg/L	22.5 oC	26.9 m3/h	0 m3/h
07:05:00	12/12/2025	7.9	10.7 mg/L	0.01 mg/L	21.6 mg/L	22.3 oC	26.3 m3/h	0 m3/h
07:10:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	21.6 mg/L	22.3 oC	27.4 m3/h	0 m3/h
07:15:00	12/12/2025	7.9	10.6 mg/L	0.02 mg/L	21.6 mg/L	22.3 oC	27.2 m3/h	0 m3/h
07:20:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	21.5 mg/L	22.3 oC	27.2 m3/h	0 m3/h
07:25:00	12/12/2025	7.9	10.8 mg/L	0.01 mg/L	21.5 mg/L	22.3 oC	27.5 m3/h	0 m3/h
07:30:00	12/12/2025	7.9	10.6 mg/L	0.02 mg/L	21.4 mg/L	22.4 oC	28.2 m3/h	0 m3/h
07:35:00	12/12/2025	7.9	10.8 mg/L	0.01 mg/L	21.5 mg/L	22.3 oC	28.3 m3/h	0 m3/h
07:40:00	12/12/2025	7.9	10.8 mg/L	0.01 mg/L	21.3 mg/L	22.3 oC	27.4 m3/h	0 m3/h
07:45:00	12/12/2025	7.9	10.6 mg/L	0.02 mg/L	21.4 mg/L	22.3 oC	28.8 m3/h	0 m3/h
07:50:00	12/12/2025	7.9	10.5 mg/L	0.01 mg/L	21.4 mg/L	22.3 oC	28.1 m3/h	0 m3/h
07:55:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	21.3 mg/L	22.4 oC	29.6 m3/h	0 m3/h

08:00:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	23.1 mg/L	22.3 oC	30.1 m3/h	0 m3/h
08:05:00	12/12/2025	7.9	10.8 mg/L	0.01 mg/L	23 mg/L	22.3 oC	30.5 m3/h	0 m3/h
08:10:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	23 mg/L	22.3 oC	29.6 m3/h	0 m3/h
08:15:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	22.9 mg/L	22.3 oC	30 m3/h	0 m3/h
08:20:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	23 mg/L	22.3 oC	30.4 m3/h	0 m3/h
08:25:00	12/12/2025	7.9	10.7 mg/L	0.03 mg/L	22.9 mg/L	22.3 oC	30.9 m3/h	0 m3/h
08:30:00	12/12/2025	7.9	10.7 mg/L	0.01 mg/L	22.9 mg/L	22.4 oC	31 m3/h	0 m3/h
08:35:00	12/12/2025	7.9	10.9 mg/L	0.03 mg/L	22.9 mg/L	22.3 oC	28.5 m3/h	0 m3/h
08:40:00	12/12/2025	7.9	10.6 mg/L	0.01 mg/L	22.9 mg/L	22.3 oC	28.7 m3/h	0 m3/h
08:45:00	12/12/2025	7.9	10.6 mg/L	0.02 mg/L	22.9 mg/L	22.3 oC	29 m3/h	0 m3/h
08:50:00	12/12/2025	7.9	10.8 mg/L	0.02 mg/L	22.9 mg/L	22.3 oC	29.1 m3/h	0 m3/h
08:55:00	12/12/2025	7.9	10.9 mg/L	0.02 mg/L	22.9 mg/L	22.3 oC	29.5 m3/h	0 m3/h
09:00:00	12/12/2025	7.9	10.9 mg/L	0.01 mg/L	21.5 mg/L	22.3 oC	29.6 m3/h	0 m3/h
09:05:00	12/12/2025	7.9	11 mg/L	0.02 mg/L	21.4 mg/L	22.3 oC	29.7 m3/h	0 m3/h
09:10:00	12/12/2025	7.9	10.7 mg/L	0.01 mg/L	21.4 mg/L	22.3 oC	30 m3/h	0 m3/h
09:15:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	21.4 mg/L	22.3 oC	29.3 m3/h	0 m3/h
09:20:00	12/12/2025	7.9	10.9 mg/L	0.02 mg/L	21.4 mg/L	22.3 oC	29.1 m3/h	0 m3/h
09:25:00	12/12/2025	7.9	10.9 mg/L	0.02 mg/L	21.4 mg/L	22.3 oC	29 m3/h	0 m3/h
09:30:00	12/12/2025	7.9	10.8 mg/L	0.02 mg/L	21.4 mg/L	22.3 oC	29.3 m3/h	0 m3/h
09:35:00	12/12/2025	7.9	10.8 mg/L	0.02 mg/L	21.4 mg/L	22.4 oC	29.1 m3/h	0 m3/h
09:40:00	12/12/2025	7.9	10.8 mg/L	0.01 mg/L	21.4 mg/L	22.3 oC	29.3 m3/h	0 m3/h
09:45:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	21.4 mg/L	22.3 oC	29.2 m3/h	0 m3/h
09:50:00	12/12/2025	7.9	10.9 mg/L	0.03 mg/L	21.4 mg/L	22.4 oC	29.3 m3/h	0 m3/h
09:55:00	12/12/2025	7.9	11 mg/L	0.02 mg/L	21.5 mg/L	22.3 oC	29.2 m3/h	0 m3/h
10:00:00	12/12/2025	7.9	10.7 mg/L	0.03 mg/L	21.9 mg/L	22.3 oC	29.4 m3/h	0 m3/h
10:05:00	12/12/2025	7.9	10.8 mg/L	0.02 mg/L	21.9 mg/L	22.3 oC	29.5 m3/h	0 m3/h
10:10:00	12/12/2025	7.9	10.9 mg/L	0.02 mg/L	21.8 mg/L	22.3 oC	29.3 m3/h	0 m3/h
10:15:00	12/12/2025	7.9	10.6 mg/L	0.02 mg/L	21.8 mg/L	22.4 oC	29.4 m3/h	0 m3/h
10:20:00	12/12/2025	7.9	10.8 mg/L	0.03 mg/L	21.9 mg/L	22.3 oC	29.3 m3/h	0 m3/h
10:25:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	21.9 mg/L	22.3 oC	29.3 m3/h	0 m3/h
10:30:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	21.9 mg/L	22.3 oC	29.3 m3/h	0 m3/h
10:35:00	12/12/2025	7.9	10.8 mg/L	0.01 mg/L	21.9 mg/L	22.4 oC	29.4 m3/h	0 m3/h
10:40:00	12/12/2025	7.9	10.9 mg/L	0.02 mg/L	21.9 mg/L	22.4 oC	29.2 m3/h	0 m3/h
10:45:00	12/12/2025	7.9	10.7 mg/L	0.03 mg/L	22 mg/L	22.3 oC	29.3 m3/h	0 m3/h
10:50:00	12/12/2025	8	10.6 mg/L	0.02 mg/L	22.1 mg/L	22.3 oC	29.3 m3/h	0 m3/h
10:55:00	12/12/2025	8	10.7 mg/L	0.02 mg/L	22 mg/L	22.4 oC	29.1 m3/h	0 m3/h
11:00:00	12/12/2025	8	10.8 mg/L	0.02 mg/L	22.4 mg/L	22.3 oC	29.3 m3/h	0 m3/h
11:05:00	12/12/2025	8	10.8 mg/L	0.02 mg/L	22.4 mg/L	22.3 oC	29.2 m3/h	0 m3/h
11:10:00	12/12/2025	7.9	10.9 mg/L	0.03 mg/L	22.4 mg/L	22.3 oC	29.1 m3/h	0 m3/h
11:15:00	12/12/2025	8	10.7 mg/L	0.01 mg/L	22.3 mg/L	22.3 oC	29.2 m3/h	0 m3/h
11:20:00	12/12/2025	8	10.5 mg/L	0.02 mg/L	22.3 mg/L	22.3 oC	29.3 m3/h	0 m3/h
11:25:00	12/12/2025	8	10.8 mg/L	0.02 mg/L	22.5 mg/L	22.3 oC	29.3 m3/h	0 m3/h
11:30:00	12/12/2025	8	10.7 mg/L	0.02 mg/L	22.5 mg/L	22.3 oC	29.2 m3/h	0 m3/h

11:35:00	12/12/2025	8	10.6 mg/L	0.02 mg/L	22.4 mg/L	22.4 oC	29.1 m3/h	0 m3/h
11:40:00	12/12/2025	8	10.9 mg/L	0.02 mg/L	22.6 mg/L	22.3 oC	29.2 m3/h	0 m3/h
11:45:00	12/12/2025	8	10.7 mg/L	0.02 mg/L	22.6 mg/L	22.3 oC	29.3 m3/h	0 m3/h
11:50:00	12/12/2025	8	10.7 mg/L	0.02 mg/L	22.5 mg/L	22.3 oC	29.3 m3/h	0 m3/h
11:55:00	12/12/2025	8	10.7 mg/L	0.01 mg/L	22.8 mg/L	22.3 oC	29.3 m3/h	0 m3/h
12:00:00	12/12/2025	7.9	10.7 mg/L	0.02 mg/L	23.3 mg/L	22.3 oC	29.3 m3/h	0 m3/h
12:05:00	12/12/2025	7.9	10.8 mg/L	0.02 mg/L	23.3 mg/L	22.3 oC	29.3 m3/h	0 m3/h
12:10:00	12/12/2025	8	10.9 mg/L	0.02 mg/L	23.1 mg/L	22.3 oC	29.3 m3/h	0 m3/h
12:15:00	12/12/2025	8	10.7 mg/L	0.02 mg/L	23.3 mg/L	22.3 oC	29.3 m3/h	0 m3/h
12:20:00	12/12/2025	8	10.9 mg/L	0.02 mg/L	23.4 mg/L	22.4 oC	29.3 m3/h	0 m3/h
12:25:00	12/12/2025	8	10.8 mg/L	0.03 mg/L	23.3 mg/L	22.5 oC	29.4 m3/h	0 m3/h
12:30:00	12/12/2025	8	10.7 mg/L	0.01 mg/L	23.4 mg/L	22.5 oC	29.4 m3/h	0 m3/h
12:35:00	12/12/2025	8	10.9 mg/L	0.02 mg/L	23.4 mg/L	22.4 oC	29.4 m3/h	0 m3/h
12:40:00	12/12/2025	8	10.8 mg/L	0.01 mg/L	23.4 mg/L	22.5 oC	29.4 m3/h	0 m3/h
12:45:00	12/12/2025	8	10.8 mg/L	0.01 mg/L	23.5 mg/L	22.4 oC	27.7 m3/h	0 m3/h
12:50:00	12/12/2025	8	10.7 mg/L	0.02 mg/L	23.4 mg/L	22.5 oC	26.5 m3/h	0 m3/h
12:55:00	12/12/2025	8	10.7 mg/L	0.01 mg/L	23.5 mg/L	22.4 oC	25.1 m3/h	0 m3/h
13:00:00	12/12/2025	8	10.9 mg/L	0.01 mg/L	23 mg/L	22.5 oC	26.2 m3/h	0 m3/h
13:05:00	12/12/2025	8	10.8 mg/L	0.02 mg/L	23 mg/L	22.4 oC	28.1 m3/h	0 m3/h
13:10:00	12/12/2025	8	10.7 mg/L	0.02 mg/L	22.9 mg/L	22.5 oC	25.5 m3/h	0 m3/h
13:15:00	12/12/2025	8	10.7 mg/L	0.01 mg/L	23.1 mg/L	22.5 oC	24.2 m3/h	0 m3/h
13:20:00	12/12/2025	8	10.8 mg/L	0.02 mg/L	23.1 mg/L	22.4 oC	28.1 m3/h	0 m3/h
13:25:00	12/12/2025	8	10.7 mg/L	0.01 mg/L	23.3 mg/L	22.4 oC	27.9 m3/h	0 m3/h
13:30:00	12/12/2025	8	10.9 mg/L	0.02 mg/L	23.1 mg/L	22.4 oC	27 m3/h	0 m3/h
13:35:00	12/12/2025	7.9	10.9 mg/L	0.01 mg/L	23.1 mg/L	22.4 oC	24.2 m3/h	0 m3/h
13:40:00	12/12/2025	7.9	10.6 mg/L	0.02 mg/L	23.1 mg/L	22.4 oC	24.9 m3/h	0 m3/h
13:45:00	12/12/2025	7.9	10.8 mg/L	0.03 mg/L	23.1 mg/L	22.4 oC	25.8 m3/h	0 m3/h
13:50:00	12/12/2025	7.9	10.8 mg/L	0.02 mg/L	23.1 mg/L	22.4 oC	24.4 m3/h	0 m3/h
13:55:00	12/12/2025	8	10.8 mg/L	0.01 mg/L	23.1 mg/L	22.5 oC	0 m3/h	0 m3/h
14:00:00	12/12/2025	8	10.8 mg/L	0.01 mg/L	23.3 mg/L	22.4 oC	0 m3/h	0 m3/h
14:05:00	12/12/2025	8	11 mg/L	0.02 mg/L	23.3 mg/L	22.4 oC	0 m3/h	0 m3/h
14:10:00	12/12/2025	8	10.7 mg/L	0.01 mg/L	23.3 mg/L	22.4 oC	0 m3/h	0 m3/h
14:15:00	12/12/2025	8	11.1 mg/L	0.01 mg/L	23.3 mg/L	22.4 oC	0 m3/h	0 m3/h
14:20:00	12/12/2025	8	10.9 mg/L	0.02 mg/L	23.4 mg/L	22.4 oC	0 m3/h	0 m3/h
14:25:00	12/12/2025	8	10.9 mg/L	0.01 mg/L	23.3 mg/L	22.5 oC	0 m3/h	0 m3/h
14:30:00	12/12/2025	8	10.4 mg/L	0.01 mg/L	23.3 mg/L	22.6 oC	0 m3/h	0 m3/h
14:35:00	12/12/2025	7.9	10.6 mg/L	0.01 mg/L	23 mg/L	22.6 oC	0 m3/h	0 m3/h
14:40:00	12/12/2025	7.9	10.6 mg/L	0.03 mg/L	21.3 mg/L	22.6 oC	0 m3/h	0 m3/h
14:45:00	12/12/2025	7.9	11.3 mg/L	0.03 mg/L	17.4 mg/L	22.6 oC	0 m3/h	0 m3/h
14:50:00	12/12/2025	7.8	15.1 mg/L	0.01 mg/L	9.94 mg/L	22.6 oC	0 m3/h	0 m3/h
14:55:00	12/12/2025	7.8	16.8 mg/L	0.02 mg/L	5.47 mg/L	22.7 oC	0 m3/h	0 m3/h
15:00:00	12/12/2025	7.7	16.5 mg/L	0.02 mg/L	0.41 mg/L	22.7 oC	0 m3/h	0 m3/h
15:05:00	12/12/2025	7.7	17.2 mg/L	0.01 mg/L	2.91 mg/L	22.7 oC	0 m3/h	0 m3/h

15:10:00	12/12/2025	7.7	18.2 mg/L	0.02 mg/L	5.44 mg/L	22.7 oC	0 m3/h	0 m3/h
15:15:00	12/12/2025	7.7	18.2 mg/L	0.02 mg/L	7.53 mg/L	22.8 oC	0 m3/h	0 m3/h
15:20:00	12/12/2025	7.7	18.7 mg/L	0.01 mg/L	8.56 mg/L	22.8 oC	0 m3/h	0 m3/h
15:25:00	12/12/2025	7.6	19.2 mg/L	0.02 mg/L	10.9 mg/L	22.8 oC	0 m3/h	0 m3/h
15:30:00	12/12/2025	7.6	19.3 mg/L	0.01 mg/L	11.3 mg/L	23 oC	0 m3/h	0 m3/h
15:35:00	12/12/2025	7.6	20.2 mg/L	0.01 mg/L	12.2 mg/L	22.9 oC	43.9 m3/h	0 m3/h
15:40:00	12/12/2025	7.6	19.9 mg/L	0.03 mg/L	12.9 mg/L	22.9 oC	27.9 m3/h	0 m3/h
15:45:00	12/12/2025	7.6	20.4 mg/L	0.02 mg/L	13.3 mg/L	23.1 oC	28.4 m3/h	0 m3/h
15:50:00	12/12/2025	7.5	20.6 mg/L	0.02 mg/L	11.8 mg/L	23.1 oC	28.8 m3/h	0 m3/h
15:55:00	12/12/2025	7.4	20.8 mg/L	0.02 mg/L	11.8 mg/L	23.2 oC	28.5 m3/h	0 m3/h
16:00:00	12/12/2025	7.4	21.1 mg/L	0.02 mg/L	14.7 mg/L	23.2 oC	28.2 m3/h	0 m3/h
16:05:00	12/12/2025	7.4	20.8 mg/L	0.02 mg/L	13.8 mg/L	23.3 oC	28.8 m3/h	0 m3/h
16:10:00	12/12/2025	7.4	21.6 mg/L	0.02 mg/L	14.4 mg/L	23.3 oC	28 m3/h	0 m3/h
16:15:00	12/12/2025	7.4	21.5 mg/L	0.01 mg/L	15.4 mg/L	23.4 oC	28.4 m3/h	0 m3/h
16:20:00	12/12/2025	7.4	21.8 mg/L	0.01 mg/L	15.5 mg/L	23.4 oC	29 m3/h	0 m3/h
16:25:00	12/12/2025	7.4	21.4 mg/L	0.02 mg/L	16 mg/L	23.5 oC	28.1 m3/h	0 m3/h
16:30:00	12/12/2025	7.3	22.2 mg/L	0.02 mg/L	16.3 mg/L	23.6 oC	28.6 m3/h	0 m3/h
16:35:00	12/12/2025	7.3	22.6 mg/L	0.02 mg/L	16.3 mg/L	23.7 oC	28.4 m3/h	0 m3/h
16:40:00	12/12/2025	7.3	22.2 mg/L	0.02 mg/L	16.4 mg/L	23.7 oC	28.3 m3/h	0 m3/h
16:45:00	12/12/2025	7.3	22.8 mg/L	0.03 mg/L	16.1 mg/L	23.9 oC	28.8 m3/h	0 m3/h
16:50:00	12/12/2025	7.3	23.6 mg/L	0.02 mg/L	15.9 mg/L	23.8 oC	28.1 m3/h	0 m3/h
16:55:00	12/12/2025	7.3	22.6 mg/L	0.02 mg/L	14.1 mg/L	23.9 oC	28.7 m3/h	0 m3/h
17:00:00	12/12/2025	7.2	22.6 mg/L	0.02 mg/L	16.4 mg/L	23.9 oC	28.1 m3/h	5.5 m3/h
17:05:00	12/12/2025	7.2	22.6 mg/L	0.02 mg/L	15.3 mg/L	23.9 oC	28.6 m3/h	12 m3/h
17:10:00	12/12/2025	7.2	23.4 mg/L	0.03 mg/L	15.1 mg/L	23.9 oC	28.5 m3/h	12.4 m3/h
17:15:00	12/12/2025	7.2	22.9 mg/L	0.02 mg/L	15.4 mg/L	24.1 oC	28.3 m3/h	13 m3/h
17:20:00	12/12/2025	7.2	23 mg/L	0.03 mg/L	16.3 mg/L	24.1 oC	28.7 m3/h	13.5 m3/h
17:25:00	12/12/2025	7.2	22.5 mg/L	0.03 mg/L	16.5 mg/L	24.2 oC	28.3 m3/h	13.8 m3/h
17:30:00	12/12/2025	7.2	23 mg/L	0.02 mg/L	17.3 mg/L	24.2 oC	29.1 m3/h	14.1 m3/h
17:35:00	12/12/2025	7.2	23.4 mg/L	0.03 mg/L	17.5 mg/L	24.2 oC	28.2 m3/h	14.5 m3/h
17:40:00	12/12/2025	7.2	23.5 mg/L	0.02 mg/L	17.6 mg/L	24.3 oC	29 m3/h	14.7 m3/h
17:45:00	12/12/2025	7.1	23 mg/L	0.01 mg/L	18 mg/L	24.3 oC	28.3 m3/h	15.2 m3/h
17:50:00	12/12/2025	7.1	23.1 mg/L	0.02 mg/L	17.1 mg/L	24.3 oC	29 m3/h	15.2 m3/h
17:55:00	12/12/2025	7.1	23.4 mg/L	0.02 mg/L	16.3 mg/L	24.5 oC	27.9 m3/h	15.5 m3/h
18:00:00	12/12/2025	7.1	23.2 mg/L	0.03 mg/L	19.5 mg/L	24.5 oC	28.5 m3/h	15.6 m3/h
18:05:00	12/12/2025	7.1	23.4 mg/L	0.01 mg/L	17.4 mg/L	24.4 oC	27.4 m3/h	15.7 m3/h
18:10:00	12/12/2025	7.1	23.6 mg/L	0.02 mg/L	17.9 mg/L	24.5 oC	28.6 m3/h	15.9 m3/h
18:15:00	12/12/2025	7.1	23.4 mg/L	0.01 mg/L	18.8 mg/L	24.5 oC	28.1 m3/h	16.1 m3/h
18:20:00	12/12/2025	7.1	24 mg/L	0.01 mg/L	19.3 mg/L	24.5 oC	29.2 m3/h	16.1 m3/h
18:25:00	12/12/2025	7.1	24.2 mg/L	0.02 mg/L	19.8 mg/L	24.6 oC	28 m3/h	16.2 m3/h
18:30:00	12/12/2025	7.1	23.6 mg/L	0.02 mg/L	20.1 mg/L	24.6 oC	29.2 m3/h	16.2 m3/h
18:35:00	12/12/2025	7.1	24 mg/L	0.02 mg/L	20.6 mg/L	24.7 oC	28.1 m3/h	16.3 m3/h
18:40:00	12/12/2025	7.1	24 mg/L	0.03 mg/L	21.5 mg/L	24.7 oC	29.1 m3/h	16.4 m3/h

18:45:00	12/12/2025	7.1	23.8 mg/L	0.03 mg/L	21.5 mg/L	24.7 oC	28.1 m3/h	16.5 m3/h
18:50:00	12/12/2025	7	24.2 mg/L	0.02 mg/L	21.1 mg/L	24.7 oC	29 m3/h	16.6 m3/h
18:55:00	12/12/2025	7	24.4 mg/L	0.01 mg/L	20 mg/L	24.8 oC	28.1 m3/h	16.5 m3/h
19:00:00	12/12/2025	7	24.8 mg/L	0.02 mg/L	22.8 mg/L	24.8 oC	29.1 m3/h	16.7 m3/h
19:05:00	12/12/2025	7	25.1 mg/L	0.01 mg/L	20.8 mg/L	24.8 oC	27.4 m3/h	17 m3/h
19:10:00	12/12/2025	7	24.3 mg/L	0.03 mg/L	21 mg/L	24.8 oC	27.9 m3/h	17.3 m3/h
19:15:00	12/12/2025	7	24.3 mg/L	0.02 mg/L	21.4 mg/L	24.8 oC	26.9 m3/h	17.9 m3/h
19:20:00	12/12/2025	7	25 mg/L	0.01 mg/L	22 mg/L	24.8 oC	27.2 m3/h	17.9 m3/h
19:25:00	12/12/2025	7	24.6 mg/L	0.01 mg/L	22.9 mg/L	25 oC	26.9 m3/h	18 m3/h
19:30:00	12/12/2025	7	24.7 mg/L	0.02 mg/L	23.6 mg/L	25 oC	27 m3/h	18.2 m3/h
19:35:00	12/12/2025	7	24.7 mg/L	0.02 mg/L	23.8 mg/L	24.9 oC	26.9 m3/h	18.4 m3/h
19:40:00	12/12/2025	7	25 mg/L	0.02 mg/L	24.1 mg/L	25 oC	26.8 m3/h	18.5 m3/h
19:45:00	12/12/2025	7	25.3 mg/L	0.02 mg/L	24.4 mg/L	25.1 oC	27.2 m3/h	18.8 m3/h
19:50:00	12/12/2025	7	25.3 mg/L	0.02 mg/L	24.1 mg/L	25.1 oC	26.7 m3/h	19 m3/h
19:55:00	12/12/2025	7	25.1 mg/L	0.03 mg/L	22.5 mg/L	25.1 oC	27.5 m3/h	19.1 m3/h
20:00:00	12/12/2025	7	25.6 mg/L	0.02 mg/L	25.1 mg/L	25.1 oC	26.7 m3/h	19.2 m3/h
20:05:00	12/12/2025	7	25 mg/L	0.02 mg/L	23.1 mg/L	25.1 oC	27.1 m3/h	19.2 m3/h
20:10:00	12/12/2025	7	25.1 mg/L	0.02 mg/L	22.5 mg/L	25 oC	27.2 m3/h	19.3 m3/h
20:15:00	12/12/2025	7	25.8 mg/L	0.02 mg/L	22.9 mg/L	25.2 oC	26.2 m3/h	19.6 m3/h
20:20:00	12/12/2025	7	25.4 mg/L	0.03 mg/L	23.1 mg/L	25.1 oC	26.7 m3/h	19.5 m3/h
20:25:00	12/12/2025	7	25.3 mg/L	0.03 mg/L	22.9 mg/L	25.1 oC	26.8 m3/h	19.5 m3/h
20:30:00	12/12/2025	6.9	25.6 mg/L	0.02 mg/L	23.3 mg/L	25.2 oC	27.1 m3/h	19.5 m3/h
20:35:00	12/12/2025	6.9	25.7 mg/L	0.02 mg/L	23.5 mg/L	25.2 oC	26 m3/h	19.6 m3/h
20:40:00	12/12/2025	6.9	26 mg/L	0.03 mg/L	23.9 mg/L	25.2 oC	26.3 m3/h	19.5 m3/h
20:45:00	12/12/2025	6.9	26.7 mg/L	0.01 mg/L	24.4 mg/L	25.1 oC	26.5 m3/h	19.6 m3/h
20:50:00	12/12/2025	6.9	26.1 mg/L	0.01 mg/L	24.8 mg/L	25.3 oC	26.5 m3/h	19.7 m3/h
20:55:00	12/12/2025	6.9	26.2 mg/L	0.03 mg/L	24.1 mg/L	25.3 oC	26.9 m3/h	19.6 m3/h
21:00:00	12/12/2025	6.9	26.3 mg/L	0.03 mg/L	26.8 mg/L	25.3 oC	26.7 m3/h	19.6 m3/h
21:05:00	12/12/2025	6.9	25.9 mg/L	0.02 mg/L	24.8 mg/L	25.3 oC	26.9 m3/h	19.8 m3/h
21:10:00	12/12/2025	6.9	26.1 mg/L	0.01 mg/L	24.5 mg/L	25.4 oC	26.7 m3/h	19.6 m3/h
21:15:00	12/12/2025	6.9	26.2 mg/L	0.01 mg/L	25 mg/L	25.3 oC	26.5 m3/h	19.7 m3/h
21:20:00	12/12/2025	6.9	26.2 mg/L	0.03 mg/L	26 mg/L	25.3 oC	26.5 m3/h	19.6 m3/h
21:25:00	12/12/2025	6.9	26.6 mg/L	0.01 mg/L	26.8 mg/L	25.4 oC	25.8 m3/h	19.7 m3/h
21:30:00	12/12/2025	6.9	27.1 mg/L	0.02 mg/L	27.4 mg/L	25.3 oC	25.2 m3/h	19.7 m3/h
21:35:00	12/12/2025	6.9	27.1 mg/L	0.01 mg/L	28.5 mg/L	25.3 oC	24.4 m3/h	19.7 m3/h
21:40:00	12/12/2025	6.9	27.1 mg/L	0.01 mg/L	28.3 mg/L	25.5 oC	25.4 m3/h	19.7 m3/h
21:45:00	12/12/2025	6.9	27 mg/L	0.02 mg/L	29 mg/L	25.5 oC	27.3 m3/h	19.7 m3/h
21:50:00	12/12/2025	6.9	27.4 mg/L	0.03 mg/L	29.5 mg/L	25.4 oC	26.8 m3/h	19.6 m3/h
21:55:00	12/12/2025	6.9	27.2 mg/L	0.01 mg/L	29 mg/L	25.5 oC	26.5 m3/h	19.7 m3/h
22:00:00	12/12/2025	6.9	26.5 mg/L	0.02 mg/L	29.6 mg/L	25.5 oC	24.6 m3/h	19.7 m3/h
22:05:00	12/12/2025	6.9	27.4 mg/L	0.02 mg/L	28 mg/L	25.4 oC	23.6 m3/h	19.6 m3/h
22:10:00	12/12/2025	6.9	27.1 mg/L	0.01 mg/L	28.1 mg/L	25.5 oC	27.9 m3/h	19.6 m3/h
22:15:00	12/12/2025	6.9	28.2 mg/L	0.02 mg/L	27.3 mg/L	25.4 oC	27.5 m3/h	19.6 m3/h

22:20:00	12/12/2025	6.9	27.7 mg/L	0.02 mg/L	27.9 mg/L	25.4 oC	25.6 m3/h	19.5 m3/h
22:25:00	12/12/2025	6.9	27.8 mg/L	0.03 mg/L	27.9 mg/L	25.6 oC	0 m3/h	19.6 m3/h
22:30:00	12/12/2025	6.9	27.9 mg/L	0.02 mg/L	28.5 mg/L	25.6 oC	0 m3/h	19.1 m3/h
22:35:00	12/12/2025	6.9	27.4 mg/L	0.01 mg/L	28.5 mg/L	25.6 oC	0 m3/h	19.1 m3/h
22:40:00	12/12/2025	6.9	28 mg/L	0.02 mg/L	29.3 mg/L	25.6 oC	0 m3/h	19 m3/h
22:45:00	12/12/2025	6.9	27.9 mg/L	0.02 mg/L	28.8 mg/L	25.5 oC	0 m3/h	15.8 m3/h
22:50:00	12/12/2025	6.9	28 mg/L	0.02 mg/L	29.9 mg/L	25.5 oC	29.3 m3/h	12.3 m3/h
22:55:00	12/12/2025	6.9	28.5 mg/L	0.01 mg/L	29.5 mg/L	25.6 oC	25.5 m3/h	9 m3/h
23:00:00	12/12/2025	6.9	27.8 mg/L	0.01 mg/L	30.3 mg/L	25.7 oC	23.3 m3/h	6.1 m3/h
23:05:00	12/12/2025	6.9	28.5 mg/L	0.02 mg/L	29.8 mg/L	25.7 oC	21.3 m3/h	4.6 m3/h
23:10:00	12/12/2025	6.9	28.8 mg/L	0.01 mg/L	30.4 mg/L	25.7 oC	21.3 m3/h	3.4 m3/h
23:15:00	12/12/2025	6.9	29 mg/L	0.02 mg/L	30.1 mg/L	25.7 oC	0 m3/h	2.5 m3/h
23:20:00	12/12/2025	6.9	29 mg/L	0.02 mg/L	31 mg/L	25.7 oC	0 m3/h	1.9 m3/h
23:25:00	12/12/2025	6.9	28.8 mg/L	0.02 mg/L	31.9 mg/L	25.7 oC	0 m3/h	1.2 m3/h
23:30:00	12/12/2025	6.9	28.8 mg/L	0.02 mg/L	32.5 mg/L	25.7 oC	0 m3/h	0 m3/h
23:35:00	12/12/2025	6.9	29.3 mg/L	0.01 mg/L	33.8 mg/L	25.6 oC	0 m3/h	0 m3/h
23:40:00	12/12/2025	6.9	29.9 mg/L	0.03 mg/L	33.8 mg/L	25.7 oC	0 m3/h	0 m3/h
23:45:00	12/12/2025	6.9	29 mg/L	0.03 mg/L	34.5 mg/L	25.6 oC	0 m3/h	0 m3/h
23:50:00	12/12/2025	6.9	29.4 mg/L	0.02 mg/L	34.8 mg/L	25.7 oC	0 m3/h	0 m3/h
23:55:00	12/12/2025	6.9	29.1 mg/L	0.03 mg/L	34.8 mg/L	25.7 oC	0 m3/h	0 m3/h
00:00:00	13/12/2025	6.9	29.8 mg/L	0.02 mg/L	34 mg/L	25.9 oC	0 m3/h	0 m3/h
00:05:00	13/12/2025	6.9	29.8 mg/L	0.02 mg/L	33.5 mg/L	25.8 oC	0 m3/h	0 m3/h
00:10:00	13/12/2025	6.9	29.4 mg/L	0.02 mg/L	33 mg/L	25.8 oC	0 m3/h	0 m3/h
00:15:00	13/12/2025	6.9	30 mg/L	0.02 mg/L	32.8 mg/L	25.8 oC	0 m3/h	0 m3/h
00:20:00	13/12/2025	6.9	30 mg/L	0.01 mg/L	32.8 mg/L	25.8 oC	0 m3/h	0 m3/h
00:25:00	13/12/2025	6.9	30.4 mg/L	0.03 mg/L	33 mg/L	25.9 oC	0 m3/h	0 m3/h
00:30:00	13/12/2025	6.9	30.4 mg/L	0.02 mg/L	32.8 mg/L	25.8 oC	0 m3/h	0 m3/h
00:35:00	13/12/2025	6.9	29.7 mg/L	0.02 mg/L	33.3 mg/L	25.8 oC	0 m3/h	0 m3/h
00:40:00	13/12/2025	6.9	29.9 mg/L	0.02 mg/L	33.5 mg/L	25.8 oC	0 m3/h	0 m3/h
00:45:00	13/12/2025	6.9	30.6 mg/L	0.03 mg/L	33.5 mg/L	25.8 oC	0 m3/h	0 m3/h
00:50:00	13/12/2025	6.9	30.2 mg/L	0.02 mg/L	33.8 mg/L	25.9 oC	0 m3/h	0 m3/h
00:55:00	13/12/2025	6.9	30.2 mg/L	0.02 mg/L	34 mg/L	25.9 oC	0 m3/h	0 m3/h
01:00:00	13/12/2025	6.9	30.4 mg/L	0.02 mg/L	33.8 mg/L	25.9 oC	0 m3/h	0 m3/h
01:05:00	13/12/2025	6.9	31 mg/L	0.03 mg/L	32.5 mg/L	26 oC	0 m3/h	0 m3/h
01:10:00	13/12/2025	6.9	30.9 mg/L	0.01 mg/L	31.9 mg/L	25.9 oC	0 m3/h	0 m3/h
01:15:00	13/12/2025	6.9	31.3 mg/L	0.01 mg/L	32.3 mg/L	25.9 oC	0 m3/h	0 m3/h
01:20:00	13/12/2025	6.9	32 mg/L	0.03 mg/L	31.9 mg/L	25.8 oC	0 m3/h	0 m3/h
01:25:00	13/12/2025	6.9	31.5 mg/L	0.02 mg/L	33 mg/L	26 oC	0 m3/h	0 m3/h
01:30:00	13/12/2025	6.9	31.6 mg/L	0.03 mg/L	33.5 mg/L	25.9 oC	0 m3/h	0 m3/h
01:35:00	13/12/2025	6.9	31.6 mg/L	0.01 mg/L	33.8 mg/L	25.9 oC	0 m3/h	0 m3/h
01:40:00	13/12/2025	6.9	31.3 mg/L	0.02 mg/L	33.5 mg/L	26 oC	0 m3/h	0 m3/h
01:45:00	13/12/2025	6.9	32.1 mg/L	0.01 mg/L	33.8 mg/L	26 oC	0 m3/h	0 m3/h
01:50:00	13/12/2025	6.9	31.9 mg/L	0.02 mg/L	34.5 mg/L	26 oC	0 m3/h	0 m3/h

01:55:00	13/12/2025	6.9	31.8 mg/L	0.02 mg/L	35 mg/L	26 oC	0 m3/h	0 m3/h
02:00:00	13/12/2025	6.9	31.8 mg/L	0.02 mg/L	35 mg/L	25.9 oC	0 m3/h	0 m3/h
02:05:00	13/12/2025	6.9	32 mg/L	0.01 mg/L	33.3 mg/L	25.9 oC	0 m3/h	0 m3/h
02:10:00	13/12/2025	6.9	32.5 mg/L	0.01 mg/L	33 mg/L	25.9 oC	0 m3/h	0 m3/h
02:15:00	13/12/2025	6.9	32.2 mg/L	0.01 mg/L	33.8 mg/L	25.9 oC	0 m3/h	0 m3/h
02:20:00	13/12/2025	6.9	32.5 mg/L	0.01 mg/L	33.3 mg/L	25.9 oC	0 m3/h	0 m3/h
02:25:00	13/12/2025	6.9	33 mg/L	0.02 mg/L	33 mg/L	26 oC	0 m3/h	0 m3/h
02:30:00	13/12/2025	6.9	33 mg/L	0.03 mg/L	33 mg/L	25.9 oC	0 m3/h	0 m3/h
02:35:00	13/12/2025	6.9	32.7 mg/L	0.02 mg/L	32.3 mg/L	26 oC	0 m3/h	0 m3/h
02:40:00	13/12/2025	6.9	32.5 mg/L	0.03 mg/L	33 mg/L	26.1 oC	0 m3/h	0 m3/h
02:45:00	13/12/2025	6.9	32.5 mg/L	0.02 mg/L	32.8 mg/L	26 oC	27.2 m3/h	0 m3/h
02:50:00	13/12/2025	6.9	33 mg/L	0.02 mg/L	33 mg/L	26.1 oC	27.4 m3/h	0 m3/h
02:55:00	13/12/2025	6.9	32.8 mg/L	0.03 mg/L	33 mg/L	26 oC	27 m3/h	0 m3/h
03:00:00	13/12/2025	6.9	32.8 mg/L	0.01 mg/L	33.5 mg/L	26.1 oC	27.1 m3/h	0 m3/h
03:05:00	13/12/2025	6.9	33 mg/L	0.02 mg/L	35 mg/L	26 oC	27.2 m3/h	0 m3/h
03:10:00	13/12/2025	6.9	33.5 mg/L	0.03 mg/L	35.8 mg/L	25.9 oC	27.2 m3/h	0 m3/h
03:15:00	13/12/2025	6.9	33.5 mg/L	0.02 mg/L	36 mg/L	25.9 oC	25.9 m3/h	0 m3/h
03:20:00	13/12/2025	6.9	33.7 mg/L	0.02 mg/L	36 mg/L	25.9 oC	24.2 m3/h	0 m3/h
03:25:00	13/12/2025	6.9	33.7 mg/L	0.02 mg/L	35.8 mg/L	26 oC	29.8 m3/h	0 m3/h
03:30:00	13/12/2025	6.9	33.4 mg/L	0.02 mg/L	35.5 mg/L	26 oC	26.9 m3/h	0 m3/h
03:35:00	13/12/2025	6.9	33.7 mg/L	0.03 mg/L	35 mg/L	26 oC	25.3 m3/h	0 m3/h
03:40:00	13/12/2025	6.9	33.5 mg/L	0.03 mg/L	35 mg/L	26 oC	27.8 m3/h	0 m3/h
03:45:00	13/12/2025	6.9	33.7 mg/L	0.01 mg/L	35.3 mg/L	25.9 oC	26.2 m3/h	0 m3/h
03:50:00	13/12/2025	6.9	33.7 mg/L	0.02 mg/L	35.3 mg/L	25.9 oC	25.5 m3/h	0 m3/h
03:55:00	13/12/2025	6.9	33.5 mg/L	0.03 mg/L	34.5 mg/L	25.9 oC	25.6 m3/h	0 m3/h
04:00:00	13/12/2025	6.9	33.7 mg/L	0.02 mg/L	34.5 mg/L	26 oC	27.3 m3/h	0 m3/h
04:05:00	13/12/2025	6.9	34.4 mg/L	0.02 mg/L	35.5 mg/L	25.9 oC	32.1 m3/h	0 m3/h
04:10:00	13/12/2025	6.9	33.9 mg/L	0.03 mg/L	36 mg/L	25.9 oC	30.7 m3/h	0 m3/h
04:15:00	13/12/2025	6.9	33.7 mg/L	0.01 mg/L	36 mg/L	25.9 oC	30.5 m3/h	0 m3/h
04:20:00	13/12/2025	6.9	33.6 mg/L	0.02 mg/L	35.8 mg/L	25.9 oC	31.4 m3/h	0 m3/h
04:25:00	13/12/2025	6.9	33.4 mg/L	0.02 mg/L	35.5 mg/L	25.9 oC	32.7 m3/h	0 m3/h
04:30:00	13/12/2025	6.9	33.9 mg/L	0.02 mg/L	35.3 mg/L	25.9 oC	31.8 m3/h	0 m3/h
04:35:00	13/12/2025	6.9	34.1 mg/L	0.01 mg/L	35 mg/L	25.9 oC	32 m3/h	0 m3/h
04:40:00	13/12/2025	6.9	33.7 mg/L	0.01 mg/L	34.5 mg/L	26 oC	32.6 m3/h	0 m3/h
04:45:00	13/12/2025	6.9	33.9 mg/L	0.02 mg/L	34.8 mg/L	25.9 oC	33.1 m3/h	0 m3/h
04:50:00	13/12/2025	6.9	33.9 mg/L	0.02 mg/L	34.5 mg/L	26 oC	31.4 m3/h	0 m3/h
04:55:00	13/12/2025	6.9	34.2 mg/L	0.02 mg/L	34.5 mg/L	25.9 oC	32.2 m3/h	0 m3/h
05:00:00	13/12/2025	6.9	34.4 mg/L	0.02 mg/L	34.5 mg/L	25.9 oC	30 m3/h	0 m3/h
05:05:00	13/12/2025	6.9	34.1 mg/L	0.02 mg/L	35.5 mg/L	26 oC	30.1 m3/h	0 m3/h
05:10:00	13/12/2025	6.9	34 mg/L	0.02 mg/L	36.3 mg/L	25.9 oC	26.7 m3/h	0 m3/h
05:15:00	13/12/2025	6.9	34.8 mg/L	0.01 mg/L	36 mg/L	26 oC	26.9 m3/h	0 m3/h
05:20:00	13/12/2025	6.9	34.3 mg/L	0.03 mg/L	36.3 mg/L	25.9 oC	26.5 m3/h	0 m3/h
05:25:00	13/12/2025	6.8	34.1 mg/L	0.02 mg/L	36.8 mg/L	25.9 oC	25.3 m3/h	0 m3/h

05:30:00	13/12/2025	6.9	34.6 mg/L	0.01 mg/L	36.3 mg/L	25.9 oC	25.7 m3/h	0 m3/h
05:35:00	13/12/2025	6.8	34.1 mg/L	0.01 mg/L	35.5 mg/L	25.9 oC	24.7 m3/h	0 m3/h
05:40:00	13/12/2025	6.8	34.6 mg/L	0.02 mg/L	35.5 mg/L	26 oC	24.9 m3/h	0 m3/h
05:45:00	13/12/2025	6.8	34.6 mg/L	0.01 mg/L	35.5 mg/L	25.9 oC	24.9 m3/h	0 m3/h
05:50:00	13/12/2025	6.8	34.6 mg/L	0.01 mg/L	35.5 mg/L	25.9 oC	25.4 m3/h	0 m3/h
05:55:00	13/12/2025	6.9	34.1 mg/L	0.02 mg/L	35.5 mg/L	26 oC	26 m3/h	0 m3/h
06:00:00	13/12/2025	6.8	34.9 mg/L	0.01 mg/L	35.8 mg/L	25.9 oC	26.9 m3/h	0 m3/h
06:05:00	13/12/2025	6.8	34.8 mg/L	0.02 mg/L	35.8 mg/L	25.9 oC	26.9 m3/h	0 m3/h
06:10:00	13/12/2025	6.8	35 mg/L	0.02 mg/L	36.3 mg/L	25.9 oC	27 m3/h	0 m3/h
06:15:00	13/12/2025	6.8	35 mg/L	0.02 mg/L	36.5 mg/L	26 oC	27.3 m3/h	0 m3/h
06:20:00	13/12/2025	6.8	35 mg/L	0.01 mg/L	36.5 mg/L	26 oC	26.5 m3/h	0 m3/h
06:25:00	13/12/2025	6.8	34.8 mg/L	0.01 mg/L	37 mg/L	25.9 oC	26.5 m3/h	0 m3/h
06:30:00	13/12/2025	6.8	35 mg/L	0.03 mg/L	36.5 mg/L	26 oC	26.8 m3/h	0 m3/h
06:35:00	13/12/2025	6.8	35 mg/L	0.01 mg/L	36.5 mg/L	25.9 oC	27 m3/h	0 m3/h
06:40:00	13/12/2025	6.8	35.1 mg/L	0.02 mg/L	36 mg/L	26 oC	27.1 m3/h	1.7 m3/h
06:45:00	13/12/2025	6.8	35.1 mg/L	0.01 mg/L	36.3 mg/L	25.9 oC	27.2 m3/h	2.7 m3/h
06:50:00	13/12/2025	6.8	34.8 mg/L	0.02 mg/L	36 mg/L	26 oC	27.3 m3/h	3.7 m3/h
06:55:00	13/12/2025	6.8	34.9 mg/L	0.02 mg/L	36.3 mg/L	25.9 oC	27.2 m3/h	4 m3/h
07:00:00	13/12/2025	6.8	35.6 mg/L	0.02 mg/L	36.3 mg/L	25.9 oC	26.7 m3/h	4.3 m3/h
07:05:00	13/12/2025	6.8	35.3 mg/L	0.02 mg/L	35.8 mg/L	26 oC	26.7 m3/h	4.8 m3/h
07:10:00	13/12/2025	6.8	36.2 mg/L	0.02 mg/L	36.3 mg/L	25.8 oC	26.7 m3/h	5.3 m3/h
07:15:00	13/12/2025	6.8	35.5 mg/L	0.03 mg/L	36.5 mg/L	25.9 oC	26.5 m3/h	6 m3/h
07:20:00	13/12/2025	6.8	35.5 mg/L	0.03 mg/L	36.5 mg/L	25.9 oC	26.6 m3/h	7.1 m3/h
07:25:00	13/12/2025	6.8	35.8 mg/L	0.01 mg/L	36.5 mg/L	25.9 oC	26.5 m3/h	8.1 m3/h
07:30:00	13/12/2025	6.8	35.5 mg/L	0.03 mg/L	36.5 mg/L	26 oC	26.5 m3/h	9.4 m3/h
07:35:00	13/12/2025	6.8	35.8 mg/L	0.02 mg/L	36.3 mg/L	25.9 oC	26.5 m3/h	10.4 m3/h
07:40:00	13/12/2025	6.8	35.5 mg/L	0.02 mg/L	36.5 mg/L	25.9 oC	26.7 m3/h	11.5 m3/h
07:45:00	13/12/2025	6.8	35.5 mg/L	0.03 mg/L	36.3 mg/L	25.9 oC	26.7 m3/h	13.5 m3/h
07:50:00	13/12/2025	6.8	35.3 mg/L	0.02 mg/L	36 mg/L	26 oC	26.9 m3/h	15.5 m3/h
07:55:00	13/12/2025	6.8	35.6 mg/L	0.01 mg/L	36 mg/L	26 oC	26.9 m3/h	17.1 m3/h
08:00:00	13/12/2025	6.8	35.6 mg/L	0.02 mg/L	35.5 mg/L	26 oC	26.9 m3/h	17.9 m3/h
08:05:00	13/12/2025	6.8	35.8 mg/L	0.01 mg/L	36.5 mg/L	25.9 oC	26.2 m3/h	18.1 m3/h
08:10:00	13/12/2025	6.8	36 mg/L	0.02 mg/L	38.5 mg/L	25.8 oC	29.2 m3/h	18.1 m3/h
08:15:00	13/12/2025	6.8	35.7 mg/L	0.02 mg/L	38.8 mg/L	25.8 oC	29.3 m3/h	17.9 m3/h
08:20:00	13/12/2025	6.8	36.2 mg/L	0.03 mg/L	39 mg/L	25.8 oC	29.1 m3/h	14.8 m3/h
08:25:00	13/12/2025	6.8	36 mg/L	0.02 mg/L	39 mg/L	25.8 oC	29.2 m3/h	12.3 m3/h
08:30:00	13/12/2025	6.8	36 mg/L	0.02 mg/L	38 mg/L	25.8 oC	27.2 m3/h	11.9 m3/h
08:35:00	13/12/2025	6.8	35.5 mg/L	0.01 mg/L	38.3 mg/L	25.9 oC	27.4 m3/h	10.5 m3/h
08:40:00	13/12/2025	6.8	36.5 mg/L	0.01 mg/L	37.8 mg/L	25.9 oC	30.5 m3/h	6.9 m3/h
08:45:00	13/12/2025	6.8	36 mg/L	0.02 mg/L	37.5 mg/L	26 oC	29.6 m3/h	5.3 m3/h
08:50:00	13/12/2025	6.8	36.3 mg/L	0.02 mg/L	38.3 mg/L	26 oC	29.9 m3/h	4.2 m3/h
08:55:00	13/12/2025	6.8	35.8 mg/L	0.02 mg/L	38.3 mg/L	25.9 oC	28.2 m3/h	2.7 m3/h
09:00:00	13/12/2025	6.8	36.1 mg/L	0.02 mg/L	39 mg/L	26 oC	27.8 m3/h	1.1 m3/h

09:05:00	13/12/2025	6.8	36.1 mg/L	0.02 mg/L	38.5 mg/L	25.9 oC	27.9 m3/h	0 m3/h
09:10:00	13/12/2025	6.8	36.3 mg/L	0.02 mg/L	38.3 mg/L	26 oC	27.7 m3/h	0 m3/h
09:15:00	13/12/2025	6.8	36.3 mg/L	0.01 mg/L	39.3 mg/L	25.9 oC	28.1 m3/h	0 m3/h
09:20:00	13/12/2025	6.8	36.5 mg/L	0.01 mg/L	39.5 mg/L	26 oC	27.3 m3/h	0 m3/h
09:25:00	13/12/2025	6.8	36.1 mg/L	0.01 mg/L	38.8 mg/L	26 oC	27.9 m3/h	0 m3/h
09:30:00	13/12/2025	6.8	36.1 mg/L	0.01 mg/L	38.8 mg/L	25.9 oC	27.5 m3/h	0 m3/h
09:35:00	13/12/2025	6.8	36.1 mg/L	0.02 mg/L	38.8 mg/L	26 oC	27.5 m3/h	0 m3/h
09:40:00	13/12/2025	6.8	36.8 mg/L	0.02 mg/L	39 mg/L	26 oC	27.3 m3/h	0 m3/h
09:45:00	13/12/2025	6.8	37.1 mg/L	0.02 mg/L	39 mg/L	26 oC	27.1 m3/h	0 m3/h
09:50:00	13/12/2025	6.8	36.6 mg/L	0.01 mg/L	40.3 mg/L	25.9 oC	26.5 m3/h	0 m3/h
09:55:00	13/12/2025	6.8	36.7 mg/L	0.02 mg/L	40.8 mg/L	26 oC	26.8 m3/h	0 m3/h
10:00:00	13/12/2025	6.8	36.9 mg/L	0.02 mg/L	41.8 mg/L	26 oC	25.8 m3/h	0 m3/h
10:05:00	13/12/2025	6.8	37 mg/L	0.01 mg/L	41 mg/L	25.9 oC	25.8 m3/h	0 m3/h
10:10:00	13/12/2025	6.8	37.1 mg/L	0.02 mg/L	40 mg/L	25.9 oC	26 m3/h	1.2 m3/h
10:15:00	13/12/2025	6.8	37.1 mg/L	0.02 mg/L	40.3 mg/L	25.9 oC	26.7 m3/h	2 m3/h
10:20:00	13/12/2025	6.8	37.1 mg/L	0.02 mg/L	41.5 mg/L	25.9 oC	26.8 m3/h	2 m3/h
10:25:00	13/12/2025	6.8	37.1 mg/L	0.02 mg/L	40.5 mg/L	26 oC	26.4 m3/h	2.1 m3/h
10:30:00	13/12/2025	6.8	37.2 mg/L	0.02 mg/L	40.5 mg/L	25.9 oC	26.5 m3/h	2.1 m3/h
10:35:00	13/12/2025	6.8	37.2 mg/L	0.02 mg/L	40.5 mg/L	25.9 oC	26.7 m3/h	2.1 m3/h
10:40:00	13/12/2025	6.8	36.9 mg/L	0.03 mg/L	40.5 mg/L	25.9 oC	26.9 m3/h	2.3 m3/h
10:45:00	13/12/2025	6.8	36.7 mg/L	0.02 mg/L	41 mg/L	26 oC	27 m3/h	2.3 m3/h
10:50:00	13/12/2025	6.8	37.2 mg/L	0.02 mg/L	41 mg/L	25.9 oC	27.4 m3/h	2.4 m3/h
10:55:00	13/12/2025	6.8	37 mg/L	0.02 mg/L	40.8 mg/L	26 oC	31.5 m3/h	2.5 m3/h
11:00:00	13/12/2025	6.8	37.5 mg/L	0.01 mg/L	43 mg/L	25.9 oC	31.7 m3/h	2.6 m3/h
11:05:00	13/12/2025	6.8	37 mg/L	0.02 mg/L	42.8 mg/L	26.1 oC	31.5 m3/h	2.7 m3/h
11:10:00	13/12/2025	6.8	37.5 mg/L	0.03 mg/L	41.3 mg/L	25.9 oC	31.8 m3/h	2.8 m3/h
11:15:00	13/12/2025	6.8	38.2 mg/L	0.01 mg/L	41.3 mg/L	25.9 oC	31.7 m3/h	2.9 m3/h
11:20:00	13/12/2025	6.8	39 mg/L	0.02 mg/L	41.5 mg/L	25.9 oC	31.7 m3/h	3.1 m3/h
11:25:00	13/12/2025	6.8	39 mg/L	0.02 mg/L	42 mg/L	26 oC	31.5 m3/h	3.3 m3/h
11:30:00	13/12/2025	6.8	38.5 mg/L	0.02 mg/L	42.8 mg/L	25.9 oC	31.2 m3/h	3.4 m3/h
11:35:00	13/12/2025	6.8	38.5 mg/L	0.02 mg/L	43.3 mg/L	25.9 oC	27 m3/h	3.6 m3/h
11:40:00	13/12/2025	6.8	37.5 mg/L	0.02 mg/L	43.3 mg/L	26.1 oC	27.7 m3/h	3.8 m3/h
11:45:00	13/12/2025	6.8	38.8 mg/L	0.01 mg/L	43.8 mg/L	26.1 oC	27.7 m3/h	4 m3/h
11:50:00	13/12/2025	6.8	38.3 mg/L	0.02 mg/L	43.8 mg/L	26 oC	32.7 m3/h	4.2 m3/h
11:55:00	13/12/2025	6.8	38.8 mg/L	0.02 mg/L	43.8 mg/L	26.1 oC	32.1 m3/h	4.4 m3/h
12:00:00	13/12/2025	6.8	39.1 mg/L	0.02 mg/L	45.3 mg/L	26 oC	33 m3/h	4.6 m3/h
12:05:00	13/12/2025	6.8	39.3 mg/L	0.02 mg/L	45.8 mg/L	26.1 oC	33 m3/h	4.8 m3/h
12:10:00	13/12/2025	6.8	39.3 mg/L	0.02 mg/L	43.5 mg/L	26 oC	32.6 m3/h	4.9 m3/h
12:15:00	13/12/2025	6.8	40.3 mg/L	0.03 mg/L	42.8 mg/L	26.1 oC	32.5 m3/h	4.9 m3/h
12:20:00	13/12/2025	6.8	39.3 mg/L	0.03 mg/L	43.8 mg/L	26.1 oC	31.3 m3/h	5 m3/h
12:25:00	13/12/2025	6.8	40.1 mg/L	0.02 mg/L	44 mg/L	26 oC	31.7 m3/h	5 m3/h
12:30:00	13/12/2025	6.8	39.8 mg/L	0.02 mg/L	43.8 mg/L	26 oC	34.7 m3/h	4.9 m3/h
12:35:00	13/12/2025	6.8	39.8 mg/L	0.02 mg/L	43.5 mg/L	26.1 oC	34.5 m3/h	5 m3/h

12:40:00	13/12/2025	6.8	40.1 mg/L	0.03 mg/L	44 mg/L	26 oC	34.5 m3/h	5 m3/h
12:45:00	13/12/2025	6.8	40.1 mg/L	0.01 mg/L	44.3 mg/L	26 oC	28.3 m3/h	5.1 m3/h
12:50:00	13/12/2025	6.8	39.9 mg/L	0.02 mg/L	44.5 mg/L	26 oC	28.8 m3/h	5.1 m3/h
12:55:00	13/12/2025	6.8	39.7 mg/L	0.02 mg/L	45.5 mg/L	26 oC	28.1 m3/h	5.1 m3/h
13:00:00	13/12/2025	6.8	39.9 mg/L	0.02 mg/L	47.5 mg/L	26.1 oC	27.4 m3/h	5.1 m3/h
13:05:00	13/12/2025	6.8	40.2 mg/L	0.02 mg/L	47 mg/L	26.1 oC	27.8 m3/h	5.1 m3/h
13:10:00	13/12/2025	6.8	40.3 mg/L	0.02 mg/L	46.8 mg/L	26.1 oC	28.2 m3/h	5.1 m3/h
13:15:00	13/12/2025	6.8	40.5 mg/L	0.01 mg/L	45.8 mg/L	26 oC	26.9 m3/h	5.1 m3/h
13:20:00	13/12/2025	6.8	40.8 mg/L	0.01 mg/L	45.8 mg/L	26.2 oC	27.7 m3/h	5.2 m3/h
13:25:00	13/12/2025	6.8	41.5 mg/L	0.02 mg/L	46 mg/L	26.2 oC	27.5 m3/h	5.2 m3/h
13:30:00	13/12/2025	6.8	37.9 mg/L	0.03 mg/L	46.5 mg/L	26.2 oC	26.5 m3/h	5.3 m3/h
13:35:00	13/12/2025	6.8	38.7 mg/L	0.01 mg/L	46.8 mg/L	26.2 oC	27.5 m3/h	5.4 m3/h
13:40:00	13/12/2025	6.8	38.5 mg/L	0.02 mg/L	46.8 mg/L	26.2 oC	27.5 m3/h	5.3 m3/h
13:45:00	13/12/2025	6.8	38.4 mg/L	0.02 mg/L	48.3 mg/L	26.1 oC	27.7 m3/h	5.4 m3/h
13:50:00	13/12/2025	6.8	38.5 mg/L	0.02 mg/L	48.3 mg/L	26.2 oC	28.5 m3/h	5.7 m3/h
13:55:00	13/12/2025	6.8	38.1 mg/L	0.02 mg/L	48.3 mg/L	26.2 oC	29.2 m3/h	5.7 m3/h
14:00:00	13/12/2025	6.8	38.8 mg/L	0.02 mg/L	49 mg/L	26.2 oC	27.9 m3/h	5.7 m3/h
14:05:00	13/12/2025	6.8	38.5 mg/L	0.02 mg/L	49.3 mg/L	26.2 oC	28 m3/h	5.2 m3/h
14:10:00	13/12/2025	6.8	38.2 mg/L	0.02 mg/L	47 mg/L	26.2 oC	28.5 m3/h	3.5 m3/h
14:15:00	13/12/2025	6.8	38.3 mg/L	0.01 mg/L	47.3 mg/L	26.1 oC	28.9 m3/h	2.4 m3/h
14:20:00	13/12/2025	6.8	38 mg/L	0.03 mg/L	47.3 mg/L	26.2 oC	28.8 m3/h	1.7 m3/h
14:25:00	13/12/2025	6.8	38.5 mg/L	0.01 mg/L	48 mg/L	26.2 oC	28.8 m3/h	1.4 m3/h
14:30:00	13/12/2025	6.8	38 mg/L	0.01 mg/L	49.5 mg/L	26.2 oC	28.9 m3/h	1.4 m3/h
14:35:00	13/12/2025	6.8	38 mg/L	0.02 mg/L	49.5 mg/L	26.2 oC	28.8 m3/h	1.7 m3/h
14:40:00	13/12/2025	6.8	38.6 mg/L	0.02 mg/L	48.5 mg/L	26.2 oC	28.6 m3/h	2.1 m3/h
14:45:00	13/12/2025	6.8	38.6 mg/L	0.02 mg/L	48.5 mg/L	26.2 oC	28.4 m3/h	2.9 m3/h
14:50:00	13/12/2025	6.8	38.5 mg/L	0.02 mg/L	49.5 mg/L	26.2 oC	28.3 m3/h	4.1 m3/h
14:55:00	13/12/2025	6.8	38.3 mg/L	0.02 mg/L	50 mg/L	26.2 oC	28.2 m3/h	5.5 m3/h
15:00:00	13/12/2025	6.8	38.7 mg/L	0.02 mg/L	50.5 mg/L	26.2 oC	28 m3/h	6.1 m3/h
15:05:00	13/12/2025	6.8	38.5 mg/L	0.02 mg/L	50.8 mg/L	26.2 oC	26.5 m3/h	6.3 m3/h
15:10:00	13/12/2025	6.8	38.4 mg/L	0.03 mg/L	49.8 mg/L	26.2 oC	25.8 m3/h	6.4 m3/h
15:15:00	13/12/2025	6.8	38.8 mg/L	0.02 mg/L	48.3 mg/L	26.2 oC	27.5 m3/h	6.4 m3/h
15:20:00	13/12/2025	6.8	38.2 mg/L	0.01 mg/L	48 mg/L	26.2 oC	27.8 m3/h	6.6 m3/h
15:25:00	13/12/2025	6.8	38.7 mg/L	0.02 mg/L	48.5 mg/L	26.2 oC	26.3 m3/h	6.8 m3/h
15:30:00	13/12/2025	6.8	38.6 mg/L	0.01 mg/L	49 mg/L	26.1 oC	26.9 m3/h	6.9 m3/h
15:35:00	13/12/2025	6.9	38.6 mg/L	0.02 mg/L	49.8 mg/L	26.2 oC	26.5 m3/h	7 m3/h
15:40:00	13/12/2025	6.9	38.4 mg/L	0.01 mg/L	50.8 mg/L	25.8 oC	24.6 m3/h	7.5 m3/h
15:45:00	13/12/2025	6.9	41.7 mg/L	0.03 mg/L	50.3 mg/L	25.1 oC	24.5 m3/h	7.7 m3/h
15:50:00	13/12/2025	6.9	40.7 mg/L	0.02 mg/L	47 mg/L	24.8 oC	24.2 m3/h	7.9 m3/h
15:55:00	13/12/2025	7	39.8 mg/L	0.03 mg/L	45.5 mg/L	24.6 oC	25.7 m3/h	8.4 m3/h
16:00:00	13/12/2025	7	38 mg/L	0.02 mg/L	42.3 mg/L	24.6 oC	26 m3/h	9.2 m3/h
16:05:00	13/12/2025	7	37.1 mg/L	0.03 mg/L	40.5 mg/L	24.4 oC	23.4 m3/h	8.8 m3/h
16:10:00	13/12/2025	7	35.6 mg/L	0.02 mg/L	37.8 mg/L	24.3 oC	24 m3/h	9.6 m3/h

16:15:00	13/12/2025	7	34.6 mg/L	0.02 mg/L	28.3 mg/L	24.2 oC	25.5 m3/h	10.3 m3/h
16:20:00	13/12/2025	7.1	34.6 mg/L	0.02 mg/L	35.5 mg/L	24.1 oC	27 m3/h	10.6 m3/h
16:25:00	13/12/2025	7.1	33.5 mg/L	0.02 mg/L	25.4 mg/L	23.8 oC	0 m3/h	11.8 m3/h
16:30:00	13/12/2025	7.1	32.4 mg/L	0.01 mg/L	22.5 mg/L	23.7 oC	0 m3/h	12.4 m3/h
16:35:00	13/12/2025	7.1	30.4 mg/L	0.02 mg/L	21.1 mg/L	23.5 oC	0 m3/h	13.1 m3/h
16:40:00	13/12/2025	7.1	29.1 mg/L	0.02 mg/L	19.6 mg/L	23.5 oC	0 m3/h	13.1 m3/h
16:45:00	13/12/2025	7.1	28.5 mg/L	0.02 mg/L	17.8 mg/L	23.2 oC	0 m3/h	13.5 m3/h
16:50:00	13/12/2025	7.1	28.5 mg/L	0.02 mg/L	18.6 mg/L	23.1 oC	0 m3/h	14 m3/h
16:55:00	13/12/2025	7.1	28.4 mg/L	0.02 mg/L	23 mg/L	23.1 oC	0 m3/h	13.5 m3/h
17:00:00	13/12/2025	7.1	27.6 mg/L	0.03 mg/L	23.4 mg/L	23 oC	0 m3/h	13.1 m3/h
17:05:00	13/12/2025	7.2	27 mg/L	0.02 mg/L	22.1 mg/L	22.8 oC	0 m3/h	12.9 m3/h
17:10:00	13/12/2025	7.2	26 mg/L	0.01 mg/L	21.1 mg/L	22.8 oC	0 m3/h	13 m3/h
17:15:00	13/12/2025	7.2	25.1 mg/L	0.02 mg/L	18.1 mg/L	22.6 oC	0 m3/h	12.8 m3/h
17:20:00	13/12/2025	7.2	24.7 mg/L	0.02 mg/L	17 mg/L	22.6 oC	0 m3/h	12.9 m3/h
17:25:00	13/12/2025	7.2	24.2 mg/L	0.01 mg/L	16 mg/L	22.6 oC	0 m3/h	12.8 m3/h
17:30:00	13/12/2025	7.2	23.8 mg/L	0.01 mg/L	15.1 mg/L	22.4 oC	0 m3/h	12.9 m3/h
17:35:00	13/12/2025	7.2	23 mg/L	0.02 mg/L	14.3 mg/L	22.5 oC	0 m3/h	13.1 m3/h
17:40:00	13/12/2025	7.2	22.6 mg/L	0.02 mg/L	13.4 mg/L	22.3 oC	0 m3/h	12.9 m3/h
17:45:00	13/12/2025	7.2	22.4 mg/L	0.02 mg/L	12.8 mg/L	22.3 oC	21.3 m3/h	13.1 m3/h
17:50:00	13/12/2025	7.2	22 mg/L	0.01 mg/L	11.9 mg/L	22.2 oC	30.5 m3/h	13.1 m3/h
17:55:00	13/12/2025	7.3	21.6 mg/L	0.02 mg/L	11.1 mg/L	22.2 oC	30.6 m3/h	13.1 m3/h
18:00:00	13/12/2025	7.3	21.3 mg/L	0.01 mg/L	11.6 mg/L	22 oC	29.9 m3/h	13.2 m3/h
18:05:00	13/12/2025	7.3	20.6 mg/L	0.02 mg/L	11 mg/L	22.1 oC	33.4 m3/h	13.2 m3/h
18:10:00	13/12/2025	7.3	20.6 mg/L	0.03 mg/L	10.5 mg/L	21.9 oC	35.3 m3/h	8 m3/h
18:15:00	13/12/2025	7.3	20.2 mg/L	0.03 mg/L	9.94 mg/L	21.9 oC	34 m3/h	4.2 m3/h
18:20:00	13/12/2025	7.3	19.9 mg/L	0.02 mg/L	9.38 mg/L	21.8 oC	32.7 m3/h	6.2 m3/h
18:25:00	13/12/2025	7.3	19.7 mg/L	0.02 mg/L	9.06 mg/L	21.8 oC	33 m3/h	6.8 m3/h
18:30:00	13/12/2025	7.3	19.1 mg/L	0.03 mg/L	8.5 mg/L	21.8 oC	32.6 m3/h	7.6 m3/h
18:35:00	13/12/2025	7.3	19 mg/L	0.02 mg/L	8.06 mg/L	21.7 oC	29.4 m3/h	8 m3/h
18:40:00	13/12/2025	7.3	18.8 mg/L	0.01 mg/L	7.5 mg/L	21.7 oC	0 m3/h	8.7 m3/h
18:45:00	13/12/2025	7.4	18.4 mg/L	0.01 mg/L	7.09 mg/L	21.6 oC	0 m3/h	9.4 m3/h
18:50:00	13/12/2025	7.4	18.1 mg/L	0.02 mg/L	6.53 mg/L	21.6 oC	0 m3/h	10.1 m3/h
18:55:00	13/12/2025	7.4	17.9 mg/L	0.01 mg/L	6.06 mg/L	21.6 oC	0 m3/h	10.6 m3/h
19:00:00	13/12/2025	7.4	17.6 mg/L	0.02 mg/L	6.06 mg/L	21.6 oC	0 m3/h	11 m3/h
19:05:00	13/12/2025	7.4	17.6 mg/L	0.03 mg/L	5.75 mg/L	21.4 oC	0 m3/h	11.3 m3/h
19:10:00	13/12/2025	7.4	17.2 mg/L	0.02 mg/L	5.53 mg/L	21.4 oC	0 m3/h	11.5 m3/h
19:15:00	13/12/2025	7.4	16.8 mg/L	0.02 mg/L	5.41 mg/L	21.4 oC	0 m3/h	11.6 m3/h
19:20:00	13/12/2025	7.4	16.9 mg/L	0.03 mg/L	4.94 mg/L	21.5 oC	0 m3/h	12 m3/h
19:25:00	13/12/2025	7.4	16.8 mg/L	0.02 mg/L	4.56 mg/L	21.3 oC	0 m3/h	12.2 m3/h
19:30:00	13/12/2025	7.4	16.7 mg/L	0.01 mg/L	4.47 mg/L	21.3 oC	0 m3/h	12.4 m3/h
19:35:00	13/12/2025	7.4	16.2 mg/L	0.03 mg/L	4.16 mg/L	21.4 oC	0 m3/h	12.4 m3/h
19:40:00	13/12/2025	7.4	16.2 mg/L	0.01 mg/L	3.92 mg/L	21.2 oC	0 m3/h	12.6 m3/h
19:45:00	13/12/2025	7.5	16.1 mg/L	0.01 mg/L	3.53 mg/L	21.1 oC	0 m3/h	12.7 m3/h

19:50:00	13/12/2025	7.5	16.1 mg/L	0.02 mg/L	3.64 mg/L	21.2 oC	0 m3/h	13 m3/h
19:55:00	13/12/2025	7.5	15.6 mg/L	0.01 mg/L	3.23 mg/L	21.2 oC	0 m3/h	12.9 m3/h
20:00:00	13/12/2025	7.5	15.8 mg/L	0.02 mg/L	2.27 mg/L	21.2 oC	0 m3/h	13 m3/h
20:05:00	13/12/2025	7.5	15.7 mg/L	0.02 mg/L	2.16 mg/L	21.2 oC	0 m3/h	13.2 m3/h
20:10:00	13/12/2025	7.5	15.6 mg/L	0.02 mg/L	1.94 mg/L	21.1 oC	0 m3/h	13.3 m3/h
20:15:00	13/12/2025	7.5	15.8 mg/L	0.02 mg/L	1.97 mg/L	21.1 oC	0 m3/h	13.3 m3/h
20:20:00	13/12/2025	7.5	15.7 mg/L	0.02 mg/L	1.74 mg/L	21.1 oC	0 m3/h	13.5 m3/h
20:25:00	13/12/2025	7.5	15.9 mg/L	0.02 mg/L	1.6 mg/L	21 oC	0 m3/h	13.6 m3/h
20:30:00	13/12/2025	7.5	15.8 mg/L	0.01 mg/L	1.47 mg/L	21 oC	0 m3/h	13.5 m3/h
20:35:00	13/12/2025	7.5	15.6 mg/L	0.02 mg/L	1.28 mg/L	21.1 oC	0 m3/h	13.2 m3/h
20:40:00	13/12/2025	7.5	15.7 mg/L	0.01 mg/L	1.14 mg/L	21.1 oC	26.7 m3/h	13.6 m3/h
20:45:00	13/12/2025	7.4	15.8 mg/L	0.02 mg/L	0.92 mg/L	21 oC	25.1 m3/h	13.7 m3/h
20:50:00	13/12/2025	7.5	15.6 mg/L	0.02 mg/L	0.15 mg/L	21 oC	25.9 m3/h	13.9 m3/h
20:55:00	13/12/2025	7.4	15.7 mg/L	0.03 mg/L	0.07 mg/L	21.1 oC	24.5 m3/h	13.9 m3/h
21:00:00	13/12/2025	7.4	15.7 mg/L	0.01 mg/L	0.35 mg/L	21.1 oC	24.6 m3/h	14 m3/h
21:05:00	13/12/2025	7.4	15.8 mg/L	0.01 mg/L	0.04 mg/L	21.1 oC	26 m3/h	14 m3/h
21:10:00	13/12/2025	7.4	15.8 mg/L	0.03 mg/L	0.14 mg/L	21.1 oC	24.4 m3/h	14.1 m3/h
21:15:00	13/12/2025	7.5	15.7 mg/L	0.02 mg/L	0.09 mg/L	21.1 oC	25.1 m3/h	14.4 m3/h
21:20:00	13/12/2025	7.4	15.6 mg/L	0.02 mg/L	0.23 mg/L	21 oC	24.9 m3/h	14.4 m3/h
21:25:00	13/12/2025	7.4	15.5 mg/L	0.01 mg/L	0.15 mg/L	21 oC	24.3 m3/h	14.4 m3/h
21:30:00	13/12/2025	7.5	15.6 mg/L	0.02 mg/L	0.29 mg/L	21.1 oC	23.3 m3/h	14.3 m3/h
21:35:00	13/12/2025	7.5	15.6 mg/L	0.02 mg/L	0.44 mg/L	21 oC	28.9 m3/h	14.5 m3/h
21:40:00	13/12/2025	7.5	15.6 mg/L	0.03 mg/L	0.59 mg/L	21.1 oC	27.6 m3/h	14.6 m3/h
21:45:00	13/12/2025	7.5	15.6 mg/L	0.02 mg/L	0.76 mg/L	21 oC	26.5 m3/h	14.6 m3/h
21:50:00	13/12/2025	7.5	15.5 mg/L	0.02 mg/L	0.7 mg/L	21 oC	25.1 m3/h	14.6 m3/h
21:55:00	13/12/2025	7.5	15.6 mg/L	0.02 mg/L	0.86 mg/L	21.1 oC	25 m3/h	14.6 m3/h
22:00:00	13/12/2025	7.4	15.4 mg/L	0.02 mg/L	1.11 mg/L	21.1 oC	25.1 m3/h	14.4 m3/h
22:05:00	13/12/2025	7.4	15.7 mg/L	0.02 mg/L	1.02 mg/L	21.1 oC	27.1 m3/h	14.6 m3/h
22:10:00	13/12/2025	7.5	15.6 mg/L	0.02 mg/L	1.05 mg/L	21 oC	28.6 m3/h	14.4 m3/h
22:15:00	13/12/2025	7.4	15.6 mg/L	0.03 mg/L	0.94 mg/L	21.1 oC	28.4 m3/h	14.4 m3/h
22:20:00	13/12/2025	7.5	15.8 mg/L	0.03 mg/L	1.23 mg/L	21 oC	28.6 m3/h	14.3 m3/h
22:25:00	13/12/2025	7.5	15.9 mg/L	0.01 mg/L	1.25 mg/L	21 oC	28.9 m3/h	14.1 m3/h
22:30:00	13/12/2025	7.5	15.8 mg/L	0.01 mg/L	1.19 mg/L	21.1 oC	28.4 m3/h	14.1 m3/h
22:35:00	13/12/2025	7.4	15.8 mg/L	0.02 mg/L	1.24 mg/L	21 oC	25.9 m3/h	14.1 m3/h
22:40:00	13/12/2025	7.5	15.9 mg/L	0.01 mg/L	1.2 mg/L	20.9 oC	24.6 m3/h	14 m3/h
22:45:00	13/12/2025	7.5	15.6 mg/L	0.01 mg/L	1.2 mg/L	20.9 oC	23.8 m3/h	14 m3/h
22:50:00	13/12/2025	7.5	15.8 mg/L	0.03 mg/L	1.38 mg/L	21 oC	24.3 m3/h	14.1 m3/h
22:55:00	13/12/2025	7.4	15.7 mg/L	0.03 mg/L	1.29 mg/L	20.9 oC	23.3 m3/h	13.9 m3/h
23:00:00	13/12/2025	7.5	15.7 mg/L	0.02 mg/L	1.39 mg/L	20.9 oC	22.5 m3/h	13.9 m3/h
23:05:00	13/12/2025	7.5	15.5 mg/L	0.02 mg/L	1.34 mg/L	20.9 oC	0 m3/h	13.8 m3/h
23:10:00	13/12/2025	7.5	15.7 mg/L	0.03 mg/L	1.46 mg/L	21 oC	0 m3/h	13.7 m3/h
23:15:00	13/12/2025	7.5	15.9 mg/L	0.03 mg/L	1.6 mg/L	21 oC	0 m3/h	10.2 m3/h
23:20:00	13/12/2025	7.5	15.7 mg/L	0.02 mg/L	1.48 mg/L	21 oC	0 m3/h	6.3 m3/h

23:25:00	13/12/2025	7.5	15.7 mg/L	0.02 mg/L	1.48 mg/L	20.9 oC	0 m3/h	2.3 m3/h
23:30:00	13/12/2025	7.5	15.9 mg/L	0.01 mg/L	1.45 mg/L	21 oC	0 m3/h	0 m3/h
23:35:00	13/12/2025	7.5	15.8 mg/L	0.01 mg/L	1.41 mg/L	20.9 oC	0 m3/h	0 m3/h
23:40:00	13/12/2025	7.5	15.5 mg/L	0.01 mg/L	1.27 mg/L	20.9 oC	0 m3/h	0 m3/h
23:45:00	13/12/2025	7.5	15.7 mg/L	0.01 mg/L	1.45 mg/L	20.9 oC	0 m3/h	0 m3/h
23:50:00	13/12/2025	7.5	16 mg/L	0.02 mg/L	1.45 mg/L	20.9 oC	0 m3/h	0 m3/h
23:55:00	13/12/2025	7.5	15.5 mg/L	0.02 mg/L	1.45 mg/L	20.9 oC	0 m3/h	0 m3/h
00:00:00	14/12/2025	7.5	15.8 mg/L	0.02 mg/L	1.52 mg/L	20.9 oC	0 m3/h	0 m3/h
00:05:00	14/12/2025	7.5	15.5 mg/L	0.01 mg/L	1.69 mg/L	20.9 oC	0 m3/h	0 m3/h
00:10:00	14/12/2025	7.5	15.6 mg/L	0.03 mg/L	1.64 mg/L	20.9 oC	0 m3/h	0 m3/h
00:15:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	1.52 mg/L	20.9 oC	0 m3/h	0 m3/h
00:20:00	14/12/2025	7.5	15.6 mg/L	0.03 mg/L	1.33 mg/L	20.9 oC	0 m3/h	2.3 m3/h
00:25:00	14/12/2025	7.5	15.5 mg/L	0.03 mg/L	1.41 mg/L	20.9 oC	0 m3/h	3.7 m3/h
00:30:00	14/12/2025	7.5	15.5 mg/L	0.02 mg/L	1.39 mg/L	21 oC	0 m3/h	5.3 m3/h
00:35:00	14/12/2025	7.5	15.5 mg/L	0.03 mg/L	1.57 mg/L	20.8 oC	0 m3/h	6.4 m3/h
00:40:00	14/12/2025	7.5	15.5 mg/L	0.02 mg/L	1.48 mg/L	20.9 oC	0 m3/h	7.4 m3/h
00:45:00	14/12/2025	7.5	15.5 mg/L	0.02 mg/L	1.61 mg/L	20.8 oC	47.9 m3/h	8.7 m3/h
00:50:00	14/12/2025	7.5	15.7 mg/L	0.02 mg/L	1.4 mg/L	20.8 oC	18.7 m3/h	9.8 m3/h
00:55:00	14/12/2025	7.5	15.5 mg/L	0.01 mg/L	1.61 mg/L	20.9 oC	38.2 m3/h	10.5 m3/h
01:00:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	1.45 mg/L	20.9 oC	38.1 m3/h	10.6 m3/h
01:05:00	14/12/2025	7.5	15.7 mg/L	0.01 mg/L	1.74 mg/L	20.8 oC	37.7 m3/h	11.2 m3/h
01:10:00	14/12/2025	7.5	15.5 mg/L	0.01 mg/L	1.87 mg/L	20.8 oC	43.2 m3/h	11.6 m3/h
01:15:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	1.81 mg/L	20.8 oC	42.6 m3/h	11.8 m3/h
01:20:00	14/12/2025	7.5	15.6 mg/L	0.01 mg/L	1.8 mg/L	20.8 oC	45.8 m3/h	12 m3/h
01:25:00	14/12/2025	7.5	15.5 mg/L	0.02 mg/L	1.75 mg/L	20.8 oC	46.2 m3/h	10.7 m3/h
01:30:00	14/12/2025	7.5	15.5 mg/L	0.02 mg/L	1.82 mg/L	20.8 oC	45.9 m3/h	11.2 m3/h
01:35:00	14/12/2025	7.5	15.5 mg/L	0.02 mg/L	1.73 mg/L	20.8 oC	45 m3/h	11.2 m3/h
01:40:00	14/12/2025	7.5	15.7 mg/L	0.03 mg/L	1.69 mg/L	20.8 oC	46.6 m3/h	11.6 m3/h
01:45:00	14/12/2025	7.5	15.5 mg/L	0.03 mg/L	1.54 mg/L	20.8 oC	46 m3/h	11.9 m3/h
01:50:00	14/12/2025	7.5	15.7 mg/L	0.02 mg/L	1.48 mg/L	20.8 oC	46.1 m3/h	12.6 m3/h
01:55:00	14/12/2025	7.5	15.7 mg/L	0.02 mg/L	1.45 mg/L	20.9 oC	45.6 m3/h	12.3 m3/h
02:00:00	14/12/2025	7.5	15.7 mg/L	0.02 mg/L	1.63 mg/L	20.8 oC	45.9 m3/h	12.8 m3/h
02:05:00	14/12/2025	7.5	15.7 mg/L	0.03 mg/L	1.27 mg/L	20.8 oC	45.5 m3/h	12.9 m3/h
02:10:00	14/12/2025	7.5	15.7 mg/L	0.02 mg/L	1.31 mg/L	20.9 oC	44 m3/h	12.6 m3/h
02:15:00	14/12/2025	7.5	15.8 mg/L	0.02 mg/L	1.09 mg/L	20.8 oC	43.3 m3/h	11.2 m3/h
02:20:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	0.96 mg/L	20.8 oC	42.6 m3/h	9.5 m3/h
02:25:00	14/12/2025	7.5	15.7 mg/L	0.02 mg/L	1.02 mg/L	20.7 oC	38.5 m3/h	8 m3/h
02:30:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	0.83 mg/L	20.7 oC	38.6 m3/h	7 m3/h
02:35:00	14/12/2025	7.5	15.9 mg/L	0.02 mg/L	1.13 mg/L	20.7 oC	35.9 m3/h	6.2 m3/h
02:40:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	1.12 mg/L	20.7 oC	36.6 m3/h	5.3 m3/h
02:45:00	14/12/2025	7.5	15.7 mg/L	0.02 mg/L	0.96 mg/L	20.7 oC	33.8 m3/h	5.1 m3/h
02:50:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	0.81 mg/L	20.7 oC	0 m3/h	5.1 m3/h
02:55:00	14/12/2025	7.5	15.8 mg/L	0.03 mg/L	0.84 mg/L	20.7 oC	0 m3/h	5.7 m3/h

03:00:00	14/12/2025	7.5	15.7 mg/L	0.01 mg/L	0.78 mg/L	20.6 oC	0 m3/h	7.2 m3/h
03:05:00	14/12/2025	7.5	15.7 mg/L	0.03 mg/L	1.42 mg/L	20.7 oC	0 m3/h	7.4 m3/h
03:10:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	1.39 mg/L	20.6 oC	0 m3/h	8.5 m3/h
03:15:00	14/12/2025	7.5	15.6 mg/L	0.03 mg/L	1.29 mg/L	20.7 oC	0 m3/h	5.7 m3/h
03:20:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	1.16 mg/L	20.7 oC	0 m3/h	1.6 m3/h
03:25:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	1.17 mg/L	20.7 oC	0 m3/h	0 m3/h
03:30:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	1.03 mg/L	20.7 oC	0 m3/h	0 m3/h
03:35:00	14/12/2025	7.5	15.5 mg/L	0.02 mg/L	0.89 mg/L	20.7 oC	0 m3/h	0 m3/h
03:40:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	0.92 mg/L	20.7 oC	0 m3/h	0 m3/h
03:45:00	14/12/2025	7.5	15.6 mg/L	0.01 mg/L	0.82 mg/L	20.7 oC	0 m3/h	0 m3/h
03:50:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	0.74 mg/L	20.7 oC	0 m3/h	0 m3/h
03:55:00	14/12/2025	7.5	15.4 mg/L	0.02 mg/L	0.8 mg/L	20.7 oC	0 m3/h	0 m3/h
04:00:00	14/12/2025	7.5	15.6 mg/L	0.01 mg/L	0.71 mg/L	20.7 oC	0 m3/h	0 m3/h
04:05:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	1.18 mg/L	20.7 oC	0 m3/h	0 m3/h
04:10:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	1.25 mg/L	20.7 oC	0 m3/h	0 m3/h
04:15:00	14/12/2025	7.5	15.8 mg/L	0.01 mg/L	1.02 mg/L	20.6 oC	0 m3/h	0 m3/h
04:20:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	1.13 mg/L	20.5 oC	0 m3/h	0 m3/h
04:25:00	14/12/2025	7.5	15.7 mg/L	0.01 mg/L	1.2 mg/L	20.5 oC	45.5 m3/h	0 m3/h
04:30:00	14/12/2025	7.5	15.7 mg/L	0.02 mg/L	0.87 mg/L	20.5 oC	27.4 m3/h	0 m3/h
04:35:00	14/12/2025	7.5	15.4 mg/L	0.02 mg/L	1.01 mg/L	20.5 oC	36.6 m3/h	0 m3/h
04:40:00	14/12/2025	7.5	15.7 mg/L	0.02 mg/L	0.99 mg/L	20.6 oC	36.1 m3/h	0 m3/h
04:45:00	14/12/2025	7.5	15.7 mg/L	0.02 mg/L	0.9 mg/L	20.5 oC	43.5 m3/h	0 m3/h
04:50:00	14/12/2025	7.5	15.5 mg/L	0.01 mg/L	0.83 mg/L	20.5 oC	50 m3/h	0 m3/h
04:55:00	14/12/2025	7.5	15.5 mg/L	0.03 mg/L	0.75 mg/L	20.5 oC	48.8 m3/h	0 m3/h
05:00:00	14/12/2025	7.5	15.8 mg/L	0.03 mg/L	0.91 mg/L	20.6 oC	47.7 m3/h	0 m3/h
05:05:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	1 mg/L	20.6 oC	43.6 m3/h	0 m3/h
05:10:00	14/12/2025	7.5	15.8 mg/L	0.02 mg/L	0.71 mg/L	20.6 oC	43.6 m3/h	0 m3/h
05:15:00	14/12/2025	7.5	15.8 mg/L	0.01 mg/L	0.94 mg/L	20.6 oC	44.9 m3/h	0 m3/h
05:20:00	14/12/2025	7.5	15.4 mg/L	0.02 mg/L	0.8 mg/L	20.6 oC	41.5 m3/h	0 m3/h
05:25:00	14/12/2025	7.5	15.8 mg/L	0.02 mg/L	0.5 mg/L	20.5 oC	40.9 m3/h	0 m3/h
05:30:00	14/12/2025	7.5	15.6 mg/L	0.01 mg/L	0.5 mg/L	20.6 oC	39.1 m3/h	0 m3/h
05:35:00	14/12/2025	7.5	15.7 mg/L	0.02 mg/L	0.41 mg/L	20.6 oC	38.2 m3/h	0 m3/h
05:40:00	14/12/2025	7.5	15.8 mg/L	0.02 mg/L	0.71 mg/L	20.4 oC	37 m3/h	0 m3/h
05:45:00	14/12/2025	7.6	15.9 mg/L	0.01 mg/L	0.72 mg/L	20.4 oC	34.9 m3/h	0 m3/h
05:50:00	14/12/2025	7.5	15.9 mg/L	0.02 mg/L	0.51 mg/L	20.5 oC	31.7 m3/h	0 m3/h
05:55:00	14/12/2025	7.6	15.9 mg/L	0.02 mg/L	0.39 mg/L	20.5 oC	31.5 m3/h	0 m3/h
06:00:00	14/12/2025	7.6	15.8 mg/L	0.02 mg/L	0.48 mg/L	20.4 oC	1.46 m3/h	0 m3/h
06:05:00	14/12/2025	7.5	15.9 mg/L	0.02 mg/L	0.47 mg/L	20.4 oC	0 m3/h	0 m3/h
06:10:00	14/12/2025	7.5	15.8 mg/L	0.01 mg/L	0.34 mg/L	20.4 oC	0 m3/h	0 m3/h
06:15:00	14/12/2025	7.5	15.8 mg/L	0.01 mg/L	0.26 mg/L	20.4 oC	0 m3/h	0 m3/h
06:20:00	14/12/2025	7.5	15.8 mg/L	0.02 mg/L	0.13 mg/L	20.4 oC	0 m3/h	0 m3/h
06:25:00	14/12/2025	7.5	15.8 mg/L	0.03 mg/L	0.02 mg/L	20.5 oC	0 m3/h	0 m3/h
06:30:00	14/12/2025	7.5	15.9 mg/L	0.02 mg/L	0.03 mg/L	20.4 oC	0 m3/h	0 m3/h

06:35:00	14/12/2025	7.5	15.9 mg/L	0.02 mg/L	0.03 mg/L	20.4 oC	0 m3/h	0 m3/h
06:40:00	14/12/2025	7.5	15.6 mg/L	0.02 mg/L	0.11 mg/L	20.5 oC	0 m3/h	0 m3/h
06:45:00	14/12/2025	7.6	15.9 mg/L	0.02 mg/L	0.16 mg/L	20.4 oC	0 m3/h	0 m3/h
06:50:00	14/12/2025	7.6	15.8 mg/L	0.01 mg/L	0.12 mg/L	20.3 oC	0 m3/h	0 m3/h
06:55:00	14/12/2025	7.6	15.8 mg/L	0.03 mg/L	0.18 mg/L	20.3 oC	0 m3/h	0 m3/h
07:00:00	14/12/2025	7.6	16 mg/L	0.01 mg/L	0.31 mg/L	20.3 oC	0 m3/h	0 m3/h
07:05:00	14/12/2025	7.6	15.7 mg/L	0.02 mg/L	0.21 mg/L	20.3 oC	0 m3/h	0 m3/h
07:10:00	14/12/2025	7.6	15.9 mg/L	0.02 mg/L	0.44 mg/L	20.4 oC	0 m3/h	0 m3/h
07:15:00	14/12/2025	7.6	15.8 mg/L	0.02 mg/L	0.49 mg/L	20.3 oC	0 m3/h	0 m3/h
07:20:00	14/12/2025	7.6	15.6 mg/L	0.01 mg/L	0.63 mg/L	20.3 oC	0 m3/h	0 m3/h
07:25:00	14/12/2025	7.6	15.5 mg/L	0.01 mg/L	0.52 mg/L	20.4 oC	0 m3/h	0 m3/h
07:30:00	14/12/2025	7.6	16 mg/L	0.03 mg/L	0.69 mg/L	20.3 oC	0 m3/h	0 m3/h
07:35:00	14/12/2025	7.6	15.4 mg/L	0.01 mg/L	0.67 mg/L	20.4 oC	30.1 m3/h	0 m3/h
07:40:00	14/12/2025	7.6	15.6 mg/L	0.01 mg/L	0.76 mg/L	20.3 oC	26.3 m3/h	0 m3/h
07:45:00	14/12/2025	7.6	15.7 mg/L	0.02 mg/L	0.7 mg/L	20.3 oC	24.2 m3/h	0 m3/h
07:50:00	14/12/2025	7.6	15.8 mg/L	0.01 mg/L	0.8 mg/L	20.3 oC	23.9 m3/h	0 m3/h
07:55:00	14/12/2025	7.5	16.9 mg/L	0.03 mg/L	5.03 mg/L	20.1 oC	22.8 m3/h	0 m3/h
08:00:00	14/12/2025	7.5	17.6 mg/L	0.01 mg/L	4.75 mg/L	20.4 oC	23.9 m3/h	0 m3/h
08:05:00	14/12/2025	7.4	17.6 mg/L	0.02 mg/L	4.47 mg/L	20.2 oC	25.6 m3/h	0 m3/h
08:10:00	14/12/2025	7.4	17.4 mg/L	0.03 mg/L	4.31 mg/L	20.1 oC	24.6 m3/h	0 m3/h
08:15:00	14/12/2025	7.5	17.2 mg/L	0.02 mg/L	4.16 mg/L	20.2 oC	24.4 m3/h	0 m3/h
08:20:00	14/12/2025	7.5	16.8 mg/L	0.02 mg/L	3.8 mg/L	20.2 oC	26 m3/h	1.5 m3/h
08:25:00	14/12/2025	7.5	16.5 mg/L	0.02 mg/L	3.36 mg/L	20.2 oC	25.5 m3/h	3.1 m3/h
08:30:00	14/12/2025	7.5	16 mg/L	0.01 mg/L	2.89 mg/L	20.2 oC	25.8 m3/h	5 m3/h
08:35:00	14/12/2025	7.5	15.9 mg/L	0.03 mg/L	2.63 mg/L	20.1 oC	24.8 m3/h	5 m3/h
08:40:00	14/12/2025	7.5	15.7 mg/L	0.01 mg/L	2 mg/L	20.1 oC	24.9 m3/h	5.2 m3/h
08:45:00	14/12/2025	7.5	15.5 mg/L	0.01 mg/L	1.55 mg/L	20.1 oC	25.1 m3/h	5.4 m3/h
08:50:00	14/12/2025	7.5	15.6 mg/L	0.01 mg/L	1.08 mg/L	20.1 oC	25.6 m3/h	5.5 m3/h
08:55:00	14/12/2025	7.5	15.4 mg/L	0.02 mg/L	0.71 mg/L	20.1 oC	25.8 m3/h	6 m3/h
09:00:00	14/12/2025	7.5	14.7 mg/L	0.01 mg/L	0.22 mg/L	20.1 oC	25.3 m3/h	6.6 m3/h
09:05:00	14/12/2025	7.5	14.7 mg/L	0.02 mg/L	0.75 mg/L	20 oC	25.5 m3/h	7 m3/h
09:10:00	14/12/2025	7.5	14.5 mg/L	0.02 mg/L	1.35 mg/L	20.2 oC	25.1 m3/h	7.8 m3/h
09:15:00	14/12/2025	7.6	14.2 mg/L	0.02 mg/L	2 mg/L	20.2 oC	26.7 m3/h	8.6 m3/h
09:20:00	14/12/2025	7.6	13.9 mg/L	0.02 mg/L	2.66 mg/L	20.3 oC	26.4 m3/h	9.5 m3/h
09:25:00	14/12/2025	7.6	14 mg/L	0.01 mg/L	3.2 mg/L	20.3 oC	26 m3/h	10.4 m3/h
09:30:00	14/12/2025	7.6	13.7 mg/L	0.02 mg/L	3.61 mg/L	20.3 oC	26.8 m3/h	10.9 m3/h
09:35:00	14/12/2025	7.6	13.7 mg/L	0.03 mg/L	3.98 mg/L	20.5 oC	26.8 m3/h	11.2 m3/h
09:40:00	14/12/2025	7.6	13.7 mg/L	0.02 mg/L	4.25 mg/L	20.5 oC	24.2 m3/h	11.8 m3/h
09:45:00	14/12/2025	7.6	13.7 mg/L	0.02 mg/L	4.31 mg/L	20.6 oC	24.8 m3/h	11.2 m3/h
09:50:00	14/12/2025	7.6	13.3 mg/L	0.03 mg/L	4.47 mg/L	20.6 oC	25.1 m3/h	11.9 m3/h
09:55:00	14/12/2025	7.6	13.1 mg/L	0.03 mg/L	4.56 mg/L	20.8 oC	26.1 m3/h	11.6 m3/h
10:00:00	14/12/2025	7.6	12.8 mg/L	0.03 mg/L	4.72 mg/L	20.9 oC	26 m3/h	11.9 m3/h
10:05:00	14/12/2025	7.6	12.9 mg/L	0.03 mg/L	4.69 mg/L	21 oC	26.5 m3/h	13 m3/h

10:10:00	14/12/2025	7.6	12.9 mg/L	0.01 mg/L	4.97 mg/L	21.1 oC	26.1 m3/h	13.1 m3/h
10:15:00	14/12/2025	7.6	12.6 mg/L	0.03 mg/L	5.13 mg/L	21.3 oC	26.5 m3/h	13.5 m3/h
10:20:00	14/12/2025	7.6	12.8 mg/L	0.01 mg/L	4.94 mg/L	21.4 oC	25.9 m3/h	13.8 m3/h
10:25:00	14/12/2025	7.6	12.6 mg/L	0.03 mg/L	5.09 mg/L	21.6 oC	25.5 m3/h	13.8 m3/h
10:30:00	14/12/2025	7.6	12.3 mg/L	0.02 mg/L	5.31 mg/L	21.7 oC	25.3 m3/h	14.1 m3/h
10:35:00	14/12/2025	7.6	12.2 mg/L	0.01 mg/L	5.47 mg/L	21.6 oC	25.3 m3/h	14.3 m3/h
10:40:00	14/12/2025	7.7	12.1 mg/L	0.02 mg/L	5.72 mg/L	21.8 oC	26 m3/h	13.8 m3/h
10:45:00	14/12/2025	7.7	12.2 mg/L	0.01 mg/L	6.09 mg/L	21.9 oC	26.5 m3/h	14.7 m3/h
10:50:00	14/12/2025	7.7	12 mg/L	0.03 mg/L	6.31 mg/L	22 oC	25.8 m3/h	14.6 m3/h
10:55:00	14/12/2025	7.7	11.7 mg/L	0.01 mg/L	6.75 mg/L	22 oC	26.3 m3/h	14.8 m3/h
11:00:00	14/12/2025	7.7	11.8 mg/L	0.02 mg/L	7.09 mg/L	21.9 oC	26.8 m3/h	14.8 m3/h
11:05:00	14/12/2025	7.7	11.8 mg/L	0.02 mg/L	7.31 mg/L	22 oC	26.1 m3/h	15 m3/h
11:10:00	14/12/2025	7.7	11.7 mg/L	0.01 mg/L	7.88 mg/L	22 oC	26.5 m3/h	14.9 m3/h
11:15:00	14/12/2025	7.7	11.7 mg/L	0.01 mg/L	8.13 mg/L	22 oC	26.6 m3/h	15 m3/h
11:20:00	14/12/2025	7.7	11.7 mg/L	0.03 mg/L	8.31 mg/L	22 oC	26.9 m3/h	14.9 m3/h
11:25:00	14/12/2025	7.7	11.6 mg/L	0.02 mg/L	8.31 mg/L	22.2 oC	26.7 m3/h	15 m3/h
11:30:00	14/12/2025	7.7	11.3 mg/L	0.01 mg/L	8.38 mg/L	22.4 oC	26.9 m3/h	15 m3/h
11:35:00	14/12/2025	7.7	11.3 mg/L	0.03 mg/L	8.44 mg/L	22.4 oC	26.7 m3/h	14.1 m3/h
11:40:00	14/12/2025	7.7	11.4 mg/L	0.02 mg/L	8.56 mg/L	22.5 oC	26.5 m3/h	14.9 m3/h
11:45:00	14/12/2025	7.7	11.3 mg/L	0.02 mg/L	8.75 mg/L	22.8 oC	26.8 m3/h	14.9 m3/h
11:50:00	14/12/2025	7.7	11.2 mg/L	0.01 mg/L	8.69 mg/L	22.9 oC	30.6 m3/h	15 m3/h
11:55:00	14/12/2025	7.7	11.3 mg/L	0.01 mg/L	8.75 mg/L	23.2 oC	31.5 m3/h	14.9 m3/h
12:00:00	14/12/2025	7.7	11.1 mg/L	0.02 mg/L	8.81 mg/L	23.4 oC	31.5 m3/h	15.2 m3/h
12:05:00	14/12/2025	7.7	11.2 mg/L	0.02 mg/L	8.75 mg/L	23.5 oC	31.2 m3/h	15.3 m3/h
12:10:00	14/12/2025	7.7	10.9 mg/L	0.02 mg/L	8.88 mg/L	23.8 oC	31.4 m3/h	15.4 m3/h
12:15:00	14/12/2025	7.7	10.7 mg/L	0.02 mg/L	8.94 mg/L	23.9 oC	32.1 m3/h	15.2 m3/h
12:20:00	14/12/2025	7.7	10.8 mg/L	0.02 mg/L	9.06 mg/L	24.2 oC	32.1 m3/h	15.5 m3/h
12:25:00	14/12/2025	7.7	10.9 mg/L	0.02 mg/L	9.19 mg/L	24.4 oC	32.4 m3/h	15.6 m3/h
12:30:00	14/12/2025	7.7	10.8 mg/L	0.03 mg/L	9.25 mg/L	24.4 oC	32.5 m3/h	15.5 m3/h
12:35:00	14/12/2025	7.7	10.6 mg/L	0.02 mg/L	9.5 mg/L	24.5 oC	32.7 m3/h	15.4 m3/h
12:40:00	14/12/2025	7.8	10.6 mg/L	0.02 mg/L	9.5 mg/L	24.7 oC	32.8 m3/h	15.5 m3/h
12:45:00	14/12/2025	7.7	10.6 mg/L	0.02 mg/L	9.69 mg/L	24.9 oC	32.4 m3/h	15.5 m3/h
12:50:00	14/12/2025	7.8	10.6 mg/L	0.02 mg/L	9.88 mg/L	25.1 oC	31.9 m3/h	15.5 m3/h
12:55:00	14/12/2025	7.8	10.5 mg/L	0.02 mg/L	10.1 mg/L	25.2 oC	32.3 m3/h	14.8 m3/h
13:00:00	14/12/2025	7.8	10.4 mg/L	0.02 mg/L	10.3 mg/L	25.3 oC	32.8 m3/h	14.1 m3/h
13:05:00	14/12/2025	7.7	10.4 mg/L	0.02 mg/L	10.4 mg/L	25.3 oC	33.1 m3/h	13.5 m3/h
13:10:00	14/12/2025	7.8	10.4 mg/L	0.02 mg/L	10.7 mg/L	25.4 oC	32.9 m3/h	12.8 m3/h
13:15:00	14/12/2025	7.8	10.5 mg/L	0.02 mg/L	10.9 mg/L	25.6 oC	33.4 m3/h	12.3 m3/h
13:20:00	14/12/2025	7.8	10.1 mg/L	0.01 mg/L	11.3 mg/L	25.6 oC	33.5 m3/h	11.8 m3/h
13:25:00	14/12/2025	7.8	10.2 mg/L	0.01 mg/L	11.5 mg/L	25.7 oC	33.8 m3/h	11.2 m3/h
13:30:00	14/12/2025	7.8	10.3 mg/L	0.02 mg/L	11.8 mg/L	25.8 oC	33.8 m3/h	11.1 m3/h
13:35:00	14/12/2025	7.8	10.2 mg/L	0.01 mg/L	12.2 mg/L	25.8 oC	33.2 m3/h	9.2 m3/h
13:40:00	14/12/2025	7.8	10.1 mg/L	0.03 mg/L	12.3 mg/L	25.8 oC	32.9 m3/h	8.9 m3/h

13:45:00	14/12/2025	7.8	10.2 mg/L	0.02 mg/L	12.4 mg/L	25.9 oC	32.2 m3/h	9.4 m3/h
13:50:00	14/12/2025	7.8	10.4 mg/L	0.02 mg/L	12.7 mg/L	25.9 oC	32.6 m3/h	9.7 m3/h
13:55:00	14/12/2025	7.8	10.4 mg/L	0.01 mg/L	12.9 mg/L	26 oC	0 m3/h	10.2 m3/h
14:00:00	14/12/2025	7.8	10.7 mg/L	0.01 mg/L	13 mg/L	26.1 oC	29 m3/h	10.3 m3/h
14:05:00	14/12/2025	7.8	10.9 mg/L	0.01 mg/L	13 mg/L	26 oC	28.3 m3/h	10.2 m3/h
14:10:00	14/12/2025	7.8	10.9 mg/L	0.02 mg/L	13.4 mg/L	26.2 oC	29.3 m3/h	9.6 m3/h
14:15:00	14/12/2025	7.8	10.3 mg/L	0.02 mg/L	13.8 mg/L	26.2 oC	27.8 m3/h	7.9 m3/h
14:20:00	14/12/2025	7.8	10.6 mg/L	0.01 mg/L	14.1 mg/L	26.1 oC	0 m3/h	9.5 m3/h
14:25:00	14/12/2025	7.7	10.7 mg/L	0.03 mg/L	14.3 mg/L	26.2 oC	28.1 m3/h	11 m3/h
14:30:00	14/12/2025	7.8	11.1 mg/L	0.01 mg/L	14.6 mg/L	26.2 oC	29 m3/h	10.9 m3/h
14:35:00	14/12/2025	7.8	11.5 mg/L	0.02 mg/L	14.8 mg/L	26.2 oC	28 m3/h	11.1 m3/h
14:40:00	14/12/2025	7.8	12.4 mg/L	0.02 mg/L	15 mg/L	26.2 oC	28.9 m3/h	11.1 m3/h
14:45:00	14/12/2025	7.8	13.3 mg/L	0.02 mg/L	15.3 mg/L	26.2 oC	28.2 m3/h	10.6 m3/h
14:50:00	14/12/2025	7.8	15.5 mg/L	0.02 mg/L	15.4 mg/L	26.2 oC	27.2 m3/h	10.3 m3/h
14:55:00	14/12/2025	7.8	18.2 mg/L	0.02 mg/L	15.6 mg/L	26.2 oC	26.6 m3/h	10.1 m3/h
15:00:00	14/12/2025	7.8	22.8 mg/L	0.03 mg/L	14.1 mg/L	26.2 oC	27.2 m3/h	10.2 m3/h
15:05:00	14/12/2025	7.7	35.1 mg/L	0.02 mg/L	14.5 mg/L	26.2 oC	26.5 m3/h	10.1 m3/h
15:10:00	14/12/2025	7.7	38.6 mg/L	0.02 mg/L	14.8 mg/L	26.1 oC	27.3 m3/h	8.4 m3/h
15:15:00	14/12/2025	7.7	10.6 mg/L	0.01 mg/L	14.9 mg/L	26.1 oC	26.6 m3/h	7 m3/h
15:20:00	14/12/2025	7.7	10.7 mg/L	0.02 mg/L	15.1 mg/L	26 oC	26.7 m3/h	5.1 m3/h
15:25:00	14/12/2025	7.7	11.2 mg/L	0.03 mg/L	15 mg/L	26.1 oC	26.1 m3/h	4.4 m3/h
15:30:00	14/12/2025	7.7	10.9 mg/L	0.02 mg/L	14.8 mg/L	26 oC	26.7 m3/h	5.1 m3/h
15:35:00	14/12/2025	7.7	10.9 mg/L	0.02 mg/L	14.5 mg/L	25.9 oC	25.6 m3/h	7 m3/h
15:40:00	14/12/2025	7.7	11.3 mg/L	0.02 mg/L	14.2 mg/L	25.8 oC	26.5 m3/h	8.1 m3/h
15:45:00	14/12/2025	7.7	11.3 mg/L	0.01 mg/L	13.7 mg/L	25.7 oC	26.1 m3/h	11.5 m3/h
15:50:00	14/12/2025	7.7	11.7 mg/L	0.02 mg/L	12.9 mg/L	25.5 oC	26 m3/h	14.3 m3/h
15:55:00	14/12/2025	7.7	12.1 mg/L	0.02 mg/L	12.4 mg/L	25.4 oC	26.7 m3/h	14.7 m3/h
16:00:00	14/12/2025	7.7	11.5 mg/L	0.01 mg/L	11.6 mg/L	25.3 oC	25.7 m3/h	15 m3/h
16:05:00	14/12/2025	7.7	11.3 mg/L	0.03 mg/L	11.2 mg/L	25.2 oC	26.3 m3/h	15.3 m3/h
16:10:00	14/12/2025	7.7	11 mg/L	0.02 mg/L	10.6 mg/L	25 oC	26.1 m3/h	15.4 m3/h
16:15:00	14/12/2025	7.7	10.2 mg/L	0.03 mg/L	9.75 mg/L	25 oC	26 m3/h	15.6 m3/h
16:20:00	14/12/2025	7.7	10.3 mg/L	0.02 mg/L	9.31 mg/L	24.8 oC	26.5 m3/h	15.7 m3/h
16:25:00	14/12/2025	7.7	10.7 mg/L	0.02 mg/L	8.88 mg/L	24.5 oC	25.5 m3/h	15.7 m3/h
16:30:00	14/12/2025	7.7	10.7 mg/L	0.02 mg/L	8.75 mg/L	24.4 oC	26.1 m3/h	15.7 m3/h
16:35:00	14/12/2025	7.7	10.4 mg/L	0.02 mg/L	8.38 mg/L	24.3 oC	26.6 m3/h	15.8 m3/h
16:40:00	14/12/2025	7.7	10.8 mg/L	0.02 mg/L	8.06 mg/L	24.2 oC	25.7 m3/h	15.7 m3/h
16:45:00	14/12/2025	7.7	10.7 mg/L	0.01 mg/L	7.81 mg/L	24 oC	26.3 m3/h	15.7 m3/h
16:50:00	14/12/2025	7.7	10.6 mg/L	0.02 mg/L	7.72 mg/L	23.9 oC	25.8 m3/h	15.6 m3/h
16:55:00	14/12/2025	7.7	10.9 mg/L	0.01 mg/L	7.5 mg/L	23.8 oC	26 m3/h	15.8 m3/h
17:00:00	14/12/2025	7.7	11.2 mg/L	0.02 mg/L	7.38 mg/L	23.7 oC	26.5 m3/h	15.7 m3/h
17:05:00	14/12/2025	7.7	10.8 mg/L	0.03 mg/L	7.38 mg/L	23.6 oC	25.5 m3/h	15.8 m3/h
17:10:00	14/12/2025	7.8	10.4 mg/L	0.02 mg/L	7.13 mg/L	23.4 oC	0 m3/h	15.6 m3/h
17:15:00	14/12/2025	7.7	10.6 mg/L	0.02 mg/L	6.91 mg/L	23.4 oC	0 m3/h	15.9 m3/h

17:20:00	14/12/2025	7.7	10.4 mg/L	0.02 mg/L	6.78 mg/L	23.3 oC	27.8 m3/h	15.7 m3/h
17:25:00	14/12/2025	7.7	10.4 mg/L	0.02 mg/L	6.75 mg/L	23.1 oC	25.3 m3/h	15.8 m3/h
17:30:00	14/12/2025	7.7	10.5 mg/L	0.01 mg/L	6.72 mg/L	23 oC	25.8 m3/h	15.7 m3/h
17:35:00	14/12/2025	7.8	10.2 mg/L	0.01 mg/L	6.66 mg/L	23 oC	26 m3/h	15.5 m3/h
17:40:00	14/12/2025	7.7	10.5 mg/L	0.01 mg/L	6.66 mg/L	22.8 oC	26.4 m3/h	11.8 m3/h
17:45:00	14/12/2025	7.8	10.5 mg/L	0.02 mg/L	6.66 mg/L	22.7 oC	26.7 m3/h	9.6 m3/h
17:50:00	14/12/2025	7.8	10.4 mg/L	0.02 mg/L	6.63 mg/L	22.7 oC	0 m3/h	7.7 m3/h
17:55:00	14/12/2025	7.8	10.6 mg/L	0.02 mg/L	6.59 mg/L	22.6 oC	0 m3/h	5.9 m3/h
18:00:00	14/12/2025	7.7	10.8 mg/L	0.02 mg/L	6.53 mg/L	22.4 oC	26 m3/h	4.8 m3/h
18:05:00	14/12/2025	7.7	10.2 mg/L	0.03 mg/L	6.97 mg/L	22.3 oC	26.7 m3/h	4.9 m3/h
18:10:00	14/12/2025	7.8	10.2 mg/L	0.01 mg/L	6.78 mg/L	22.3 oC	25.7 m3/h	4.8 m3/h
18:15:00	14/12/2025	7.8	10.6 mg/L	0.02 mg/L	6.72 mg/L	22.2 oC	26.6 m3/h	4.4 m3/h
18:20:00	14/12/2025	7.8	10.3 mg/L	0.02 mg/L	6.72 mg/L	22.1 oC	25.4 m3/h	5.3 m3/h
18:25:00	14/12/2025	7.7	10.4 mg/L	0.01 mg/L	6.75 mg/L	22 oC	26.5 m3/h	5.9 m3/h
18:30:00	14/12/2025	7.8	10.5 mg/L	0.02 mg/L	6.88 mg/L	21.9 oC	24.5 m3/h	7.4 m3/h
18:35:00	14/12/2025	7.7	10.5 mg/L	0.03 mg/L	6.78 mg/L	21.9 oC	0 m3/h	9.2 m3/h
18:40:00	14/12/2025	7.8	10.5 mg/L	0.02 mg/L	6.84 mg/L	21.8 oC	0 m3/h	10.1 m3/h
18:45:00	14/12/2025	7.7	10.7 mg/L	0.02 mg/L	7 mg/L	21.6 oC	0 m3/h	10.6 m3/h
18:50:00	14/12/2025	7.8	10.6 mg/L	0.02 mg/L	6.88 mg/L	21.7 oC	25.7 m3/h	6.6 m3/h
18:55:00	14/12/2025	7.8	10.3 mg/L	0.02 mg/L	6.88 mg/L	21.6 oC	25.9 m3/h	1.5 m3/h
19:00:00	14/12/2025	7.8	10.7 mg/L	0.01 mg/L	6.88 mg/L	21.5 oC	24.9 m3/h	0 m3/h
19:05:00	14/12/2025	7.7	10.6 mg/L	0.03 mg/L	7.16 mg/L	21.4 oC	25.8 m3/h	0 m3/h
19:10:00	14/12/2025	7.7	10.7 mg/L	0.02 mg/L	6.97 mg/L	21.4 oC	24.8 m3/h	0 m3/h
19:15:00	14/12/2025	7.8	10.6 mg/L	0.02 mg/L	6.94 mg/L	21.5 oC	26.4 m3/h	0 m3/h
19:20:00	14/12/2025	7.8	10.9 mg/L	0.02 mg/L	6.88 mg/L	21.3 oC	24.5 m3/h	0 m3/h
19:25:00	14/12/2025	7.8	10.6 mg/L	0.01 mg/L	7 mg/L	21.4 oC	29.5 m3/h	0 m3/h
19:30:00	14/12/2025	7.8	10.7 mg/L	0.03 mg/L	7.16 mg/L	21.4 oC	28.2 m3/h	0 m3/h
19:35:00	14/12/2025	7.8	10.7 mg/L	0.02 mg/L	7.06 mg/L	21.2 oC	29.1 m3/h	0 m3/h
19:40:00	14/12/2025	7.8	10.8 mg/L	0.02 mg/L	7.22 mg/L	21.1 oC	28.1 m3/h	0 m3/h
19:45:00	14/12/2025	7.8	10.7 mg/L	0.02 mg/L	7.31 mg/L	21.2 oC	28.8 m3/h	0 m3/h
19:50:00	14/12/2025	7.8	10.6 mg/L	0.01 mg/L	7.22 mg/L	21 oC	28 m3/h	0 m3/h
19:55:00	14/12/2025	7.8	10.7 mg/L	0.03 mg/L	7.25 mg/L	21.1 oC	28.6 m3/h	0 m3/h
20:00:00	14/12/2025	7.8	10.5 mg/L	0.02 mg/L	7.28 mg/L	21 oC	27 m3/h	0 m3/h
20:05:00	14/12/2025	7.7	10.6 mg/L	0.03 mg/L	7.59 mg/L	21 oC	27.3 m3/h	0 m3/h
20:10:00	14/12/2025	7.8	10.5 mg/L	0.01 mg/L	7.5 mg/L	20.9 oC	26.8 m3/h	0 m3/h
20:15:00	14/12/2025	7.8	10.7 mg/L	0.03 mg/L	7.44 mg/L	21 oC	27 m3/h	0 m3/h
20:20:00	14/12/2025	7.8	10.8 mg/L	0.02 mg/L	7.31 mg/L	21 oC	28.6 m3/h	0 m3/h
20:25:00	14/12/2025	7.8	10.6 mg/L	0.01 mg/L	7.31 mg/L	21 oC	28.7 m3/h	0 m3/h
20:30:00	14/12/2025	7.8	10.7 mg/L	0.02 mg/L	7.31 mg/L	20.9 oC	28.4 m3/h	0 m3/h
20:35:00	14/12/2025	7.8	10.7 mg/L	0.02 mg/L	7.31 mg/L	20.9 oC	28.6 m3/h	0 m3/h
20:40:00	14/12/2025	7.8	10.8 mg/L	0.02 mg/L	7.38 mg/L	20.8 oC	28.3 m3/h	0 m3/h
20:45:00	14/12/2025	7.8	10.6 mg/L	0.02 mg/L	7.31 mg/L	20.8 oC	28.7 m3/h	0 m3/h
20:50:00	14/12/2025	7.8	10.6 mg/L	0.02 mg/L	7.31 mg/L	20.7 oC	28.2 m3/h	0 m3/h

20:55:00	14/12/2025	7.7	10.7 mg/L	0.03 mg/L	7.34 mg/L	20.6 oC	29 m3/h	0 m3/h
21:00:00	14/12/2025	7.8	10.8 mg/L	0.02 mg/L	7.28 mg/L	20.7 oC	28.2 m3/h	0 m3/h
21:05:00	14/12/2025	7.8	10.8 mg/L	0.03 mg/L	7.44 mg/L	20.7 oC	27.9 m3/h	0 m3/h
21:10:00	14/12/2025	7.8	10.6 mg/L	0.02 mg/L	7.13 mg/L	20.6 oC	26.5 m3/h	0 m3/h
21:15:00	14/12/2025	7.8	10.7 mg/L	0.03 mg/L	6.94 mg/L	20.6 oC	27.3 m3/h	0 m3/h
21:20:00	14/12/2025	7.8	10.7 mg/L	0.01 mg/L	6.69 mg/L	20.6 oC	26.7 m3/h	0 m3/h
21:25:00	14/12/2025	7.7	10.7 mg/L	0.02 mg/L	6.56 mg/L	20.4 oC	27.2 m3/h	0 m3/h
21:30:00	14/12/2025	7.7	10.6 mg/L	0.03 mg/L	6.41 mg/L	20.4 oC	45.6 m3/h	0 m3/h
21:35:00	14/12/2025	7.8	10.5 mg/L	0.02 mg/L	6.25 mg/L	20.4 oC	46.4 m3/h	0 m3/h
21:40:00	14/12/2025	7.7	10.9 mg/L	0.02 mg/L	5.97 mg/L	20.3 oC	46.1 m3/h	0 m3/h
21:45:00	14/12/2025	7.8	10.7 mg/L	0.03 mg/L	5.94 mg/L	20.3 oC	45.6 m3/h	0 m3/h
21:50:00	14/12/2025	7.7	10.5 mg/L	0.02 mg/L	5.63 mg/L	20.4 oC	46.6 m3/h	0 m3/h
21:55:00	14/12/2025	7.8	10.7 mg/L	0.03 mg/L	5.63 mg/L	20.2 oC	47 m3/h	0 m3/h
22:00:00	14/12/2025	7.7	10.4 mg/L	0.03 mg/L	5.41 mg/L	20.2 oC	45.3 m3/h	0 m3/h
22:05:00	14/12/2025	7.7	10.7 mg/L	0.02 mg/L	5.69 mg/L	20 oC	45.9 m3/h	0 m3/h
22:10:00	14/12/2025	7.7	10.7 mg/L	0.01 mg/L	5.41 mg/L	20.1 oC	46.3 m3/h	0 m3/h
22:15:00	14/12/2025	7.7	10.5 mg/L	0.03 mg/L	5.31 mg/L	20.1 oC	46.5 m3/h	0 m3/h
22:20:00	14/12/2025	7.7	10.7 mg/L	0.02 mg/L	5.34 mg/L	20 oC	46.3 m3/h	0 m3/h
22:25:00	14/12/2025	7.7	10.6 mg/L	0.02 mg/L	5.28 mg/L	20.1 oC	46.6 m3/h	0 m3/h
22:30:00	14/12/2025	7.7	10.5 mg/L	0.03 mg/L	5.25 mg/L	20.1 oC	46.1 m3/h	0 m3/h
22:35:00	14/12/2025	7.7	11 mg/L	0.01 mg/L	5.25 mg/L	20.1 oC	45.9 m3/h	0 m3/h
22:40:00	14/12/2025	7.7	10.6 mg/L	0.01 mg/L	5.41 mg/L	19.9 oC	45.5 m3/h	0 m3/h
22:45:00	14/12/2025	7.7	10.7 mg/L	0.01 mg/L	5.44 mg/L	20 oC	44.9 m3/h	0 m3/h
22:50:00	14/12/2025	7.7	10.7 mg/L	0.02 mg/L	5.5 mg/L	20 oC	44.3 m3/h	0 m3/h
22:55:00	14/12/2025	7.7	10.5 mg/L	0.02 mg/L	5.66 mg/L	20 oC	43.7 m3/h	0 m3/h
23:00:00	14/12/2025	7.7	10.6 mg/L	0.03 mg/L	5.78 mg/L	20 oC	43 m3/h	0 m3/h
23:05:00	14/12/2025	7.7	10.6 mg/L	0.02 mg/L	5.97 mg/L	20 oC	42.5 m3/h	0 m3/h
23:10:00	14/12/2025	7.7	11 mg/L	0.03 mg/L	5.97 mg/L	19.9 oC	41.1 m3/h	0 m3/h
23:15:00	14/12/2025	7.7	10.8 mg/L	0.01 mg/L	5.97 mg/L	19.9 oC	38.6 m3/h	0 m3/h
23:20:00	14/12/2025	7.7	10.6 mg/L	0.01 mg/L	6 mg/L	19.9 oC	36.1 m3/h	0 m3/h
23:25:00	14/12/2025	7.7	10.7 mg/L	0.02 mg/L	6 mg/L	20 oC	33.6 m3/h	0 m3/h
23:30:00	14/12/2025	7.7	10.6 mg/L	0.02 mg/L	6.09 mg/L	19.9 oC	31.2 m3/h	0 m3/h
23:35:00	14/12/2025	7.7	10.6 mg/L	0.02 mg/L	6.13 mg/L	19.9 oC	32.1 m3/h	0 m3/h
23:40:00	14/12/2025	7.7	10.6 mg/L	0.01 mg/L	6.16 mg/L	20 oC	0 m3/h	0 m3/h
23:45:00	14/12/2025	7.7	10.5 mg/L	0.02 mg/L	6.16 mg/L	19.9 oC	0 m3/h	0 m3/h
23:50:00	14/12/2025	7.7	10.6 mg/L	0.01 mg/L	6.22 mg/L	19.8 oC	0 m3/h	0 m3/h
23:55:00	14/12/2025	7.7	10.6 mg/L	0.02 mg/L	6.22 mg/L	19.8 oC	0 m3/h	0 m3/h
00:00:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	6.16 mg/L	19.9 oC	0 m3/h	0 m3/h
00:05:00	15/12/2025	7.7	10.7 mg/L	0.01 mg/L	6.72 mg/L	19.8 oC	0 m3/h	0 m3/h
00:10:00	15/12/2025	7.7	11 mg/L	0.02 mg/L	6.63 mg/L	19.9 oC	0 m3/h	0 m3/h
00:15:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	6.56 mg/L	19.8 oC	0 m3/h	0 m3/h
00:20:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	6.59 mg/L	19.8 oC	0 m3/h	0 m3/h
00:25:00	15/12/2025	7.7	10.4 mg/L	0.01 mg/L	6.56 mg/L	19.8 oC	0 m3/h	0 m3/h

00:30:00	15/12/2025	7.7	10.6 mg/L	0.01 mg/L	6.59 mg/L	19.8 oC	0 m3/h	0 m3/h
00:35:00	15/12/2025	7.7	10.6 mg/L	0.01 mg/L	6.63 mg/L	19.8 oC	0 m3/h	0 m3/h
00:40:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	6.66 mg/L	19.8 oC	0 m3/h	0 m3/h
00:45:00	15/12/2025	7.7	10.8 mg/L	0.02 mg/L	6.75 mg/L	19.8 oC	0 m3/h	0 m3/h
00:50:00	15/12/2025	7.7	10.7 mg/L	0.01 mg/L	6.72 mg/L	19.9 oC	0 m3/h	0 m3/h
00:55:00	15/12/2025	7.7	10.7 mg/L	0.01 mg/L	6.72 mg/L	19.8 oC	0 m3/h	0 m3/h
01:00:00	15/12/2025	7.7	10.6 mg/L	0.01 mg/L	6.66 mg/L	19.7 oC	0 m3/h	0 m3/h
01:05:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	7.03 mg/L	19.7 oC	0 m3/h	0 m3/h
01:10:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	6.97 mg/L	19.6 oC	0 m3/h	0 m3/h
01:15:00	15/12/2025	7.7	10.7 mg/L	0.01 mg/L	7 mg/L	19.6 oC	0 m3/h	0 m3/h
01:20:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	7 mg/L	19.6 oC	0 m3/h	0 m3/h
01:25:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	6.94 mg/L	19.7 oC	0 m3/h	0 m3/h
01:30:00	15/12/2025	7.7	10.7 mg/L	0.01 mg/L	6.81 mg/L	19.7 oC	0 m3/h	0 m3/h
01:35:00	15/12/2025	7.7	10.8 mg/L	0.01 mg/L	6.97 mg/L	19.6 oC	0 m3/h	0 m3/h
01:40:00	15/12/2025	7.7	10.8 mg/L	0.03 mg/L	6.75 mg/L	19.7 oC	0 m3/h	0 m3/h
01:45:00	15/12/2025	7.7	10.8 mg/L	0.01 mg/L	6.66 mg/L	19.6 oC	0 m3/h	0 m3/h
01:50:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	6.69 mg/L	19.7 oC	0 m3/h	0 m3/h
01:55:00	15/12/2025	7.7	10.6 mg/L	0.01 mg/L	6.44 mg/L	19.7 oC	0 m3/h	0 m3/h
02:00:00	15/12/2025	7.7	10.6 mg/L	0.03 mg/L	6.28 mg/L	19.6 oC	0 m3/h	0 m3/h
02:05:00	15/12/2025	7.7	10.5 mg/L	0.01 mg/L	6.59 mg/L	19.6 oC	0 m3/h	0 m3/h
02:10:00	15/12/2025	7.7	10.4 mg/L	0.02 mg/L	6.5 mg/L	19.6 oC	0 m3/h	0 m3/h
02:15:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	6.03 mg/L	19.5 oC	44.1 m3/h	0 m3/h
02:20:00	15/12/2025	7.7	10.8 mg/L	0.01 mg/L	5.84 mg/L	19.6 oC	37.5 m3/h	0 m3/h
02:25:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	5.75 mg/L	19.6 oC	36.6 m3/h	0 m3/h
02:30:00	15/12/2025	7.7	10.4 mg/L	0.02 mg/L	5.69 mg/L	19.6 oC	35.8 m3/h	0 m3/h
02:35:00	15/12/2025	7.7	10.7 mg/L	0.01 mg/L	5.5 mg/L	19.8 oC	36.4 m3/h	0 m3/h
02:40:00	15/12/2025	7.7	11 mg/L	0.01 mg/L	5.44 mg/L	19.8 oC	36.3 m3/h	0 m3/h
02:45:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	5.28 mg/L	19.7 oC	42.4 m3/h	0 m3/h
02:50:00	15/12/2025	7.7	10.9 mg/L	0.01 mg/L	5.19 mg/L	19.7 oC	42.5 m3/h	0 m3/h
02:55:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	5.03 mg/L	19.5 oC	41.7 m3/h	0 m3/h
03:00:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	5.09 mg/L	19.8 oC	36.7 m3/h	0 m3/h
03:05:00	15/12/2025	7.7	10.7 mg/L	0.03 mg/L	5.53 mg/L	19.8 oC	35.3 m3/h	0 m3/h
03:10:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	5.41 mg/L	19.7 oC	34.7 m3/h	0 m3/h
03:15:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	5.34 mg/L	19.7 oC	30.2 m3/h	0 m3/h
03:20:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	5.41 mg/L	19.8 oC	28.1 m3/h	0 m3/h
03:25:00	15/12/2025	7.7	10.7 mg/L	0.01 mg/L	5.47 mg/L	19.7 oC	2.23 m3/h	0 m3/h
03:30:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	5.47 mg/L	19.8 oC	0 m3/h	0 m3/h
03:35:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	5.63 mg/L	19.7 oC	0 m3/h	0 m3/h
03:40:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	5.66 mg/L	19.7 oC	0 m3/h	0 m3/h
03:45:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	5.66 mg/L	19.7 oC	0 m3/h	0 m3/h
03:50:00	15/12/2025	7.7	10.7 mg/L	0.01 mg/L	5.66 mg/L	19.8 oC	0 m3/h	0 m3/h
03:55:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	5.72 mg/L	19.7 oC	0 m3/h	0 m3/h
04:00:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	5.53 mg/L	19.7 oC	0 m3/h	0 m3/h

04:05:00	15/12/2025	7.7	10.4 mg/L	0.03 mg/L	5.78 mg/L	19.7 oC	0 m3/h	0 m3/h
04:10:00	15/12/2025	7.7	10.5 mg/L	0.01 mg/L	5.56 mg/L	19.8 oC	0 m3/h	0 m3/h
04:15:00	15/12/2025	7.7	10.6 mg/L	0.03 mg/L	5.5 mg/L	19.8 oC	0 m3/h	0 m3/h
04:20:00	15/12/2025	7.7	10.6 mg/L	0.01 mg/L	5.38 mg/L	19.7 oC	0 m3/h	0 m3/h
04:25:00	15/12/2025	7.7	11.2 mg/L	0.02 mg/L	5.19 mg/L	19.8 oC	0 m3/h	0 m3/h
04:30:00	15/12/2025	7.7	10.8 mg/L	0.02 mg/L	5.31 mg/L	19.7 oC	0 m3/h	0 m3/h
04:35:00	15/12/2025	7.7	10.5 mg/L	0.01 mg/L	5 mg/L	19.7 oC	0 m3/h	0 m3/h
04:40:00	15/12/2025	7.7	10.5 mg/L	0.03 mg/L	4.94 mg/L	19.8 oC	0 m3/h	0 m3/h
04:45:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	4.91 mg/L	19.7 oC	0 m3/h	0 m3/h
04:50:00	15/12/2025	7.7	10.3 mg/L	0.02 mg/L	4.88 mg/L	19.7 oC	46.4 m3/h	0 m3/h
04:55:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	4.84 mg/L	19.8 oC	32.3 m3/h	0 m3/h
05:00:00	15/12/2025	7.7	10.6 mg/L	0.01 mg/L	4.94 mg/L	19.8 oC	35.9 m3/h	0 m3/h
05:05:00	15/12/2025	7.7	10.6 mg/L	0.03 mg/L	5.34 mg/L	19.7 oC	33.5 m3/h	0 m3/h
05:10:00	15/12/2025	7.7	10.8 mg/L	0.02 mg/L	5.41 mg/L	19.7 oC	33 m3/h	0 m3/h
05:15:00	15/12/2025	7.7	10.6 mg/L	0.03 mg/L	5.22 mg/L	19.7 oC	32.5 m3/h	0 m3/h
05:20:00	15/12/2025	7.7	10.6 mg/L	0.01 mg/L	5.28 mg/L	19.7 oC	36.1 m3/h	0 m3/h
05:25:00	15/12/2025	7.7	10.7 mg/L	0.01 mg/L	5.31 mg/L	19.8 oC	31.2 m3/h	0 m3/h
05:30:00	15/12/2025	7.7	10.6 mg/L	0.03 mg/L	5.34 mg/L	19.8 oC	0 m3/h	0 m3/h
05:35:00	15/12/2025	7.7	10.7 mg/L	0.03 mg/L	5.38 mg/L	19.8 oC	0 m3/h	0 m3/h
05:40:00	15/12/2025	7.7	10.8 mg/L	0.02 mg/L	5.41 mg/L	19.7 oC	0 m3/h	0 m3/h
05:45:00	15/12/2025	7.7	10.7 mg/L	0.03 mg/L	5.41 mg/L	19.7 oC	0 m3/h	0 m3/h
05:50:00	15/12/2025	7.7	10.6 mg/L	0.01 mg/L	5.5 mg/L	19.7 oC	0 m3/h	0 m3/h
05:55:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	5.63 mg/L	19.7 oC	0 m3/h	0 m3/h
06:00:00	15/12/2025	7.7	10.7 mg/L	0.01 mg/L	5.66 mg/L	19.7 oC	0 m3/h	0 m3/h
06:05:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	6.03 mg/L	19.7 oC	0 m3/h	0 m3/h
06:10:00	15/12/2025	7.7	10.7 mg/L	0.01 mg/L	6 mg/L	19.8 oC	0 m3/h	0 m3/h
06:15:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	5.88 mg/L	19.7 oC	0 m3/h	0 m3/h
06:20:00	15/12/2025	7.7	10.7 mg/L	0.01 mg/L	5.88 mg/L	19.8 oC	0 m3/h	0 m3/h
06:25:00	15/12/2025	7.7	10.5 mg/L	0.01 mg/L	5.69 mg/L	19.7 oC	0 m3/h	0 m3/h
06:30:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	5.56 mg/L	19.8 oC	0 m3/h	0 m3/h
06:35:00	15/12/2025	7.7	10.8 mg/L	0.02 mg/L	5.53 mg/L	19.8 oC	0 m3/h	0 m3/h
06:40:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	5.28 mg/L	19.8 oC	0 m3/h	0 m3/h
06:45:00	15/12/2025	7.7	10.6 mg/L	0.03 mg/L	5.19 mg/L	19.7 oC	0 m3/h	0 m3/h
06:50:00	15/12/2025	7.7	10.7 mg/L	0.01 mg/L	5.06 mg/L	19.7 oC	0 m3/h	0 m3/h
06:55:00	15/12/2025	7.7	10.6 mg/L	0.03 mg/L	4.91 mg/L	19.7 oC	5.47 m3/h	0 m3/h
07:00:00	15/12/2025	7.7	10.6 mg/L	0.03 mg/L	4.75 mg/L	19.7 oC	14.6 m3/h	0 m3/h
07:05:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	5.25 mg/L	19.8 oC	26.5 m3/h	0 m3/h
07:10:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	5 mg/L	19.8 oC	25.7 m3/h	0 m3/h
07:15:00	15/12/2025	7.7	10.4 mg/L	0.01 mg/L	4.94 mg/L	19.8 oC	25.6 m3/h	0 m3/h
07:20:00	15/12/2025	7.7	11 mg/L	0.01 mg/L	4.88 mg/L	19.7 oC	26 m3/h	0 m3/h
07:25:00	15/12/2025	7.7	10.6 mg/L	0.01 mg/L	4.94 mg/L	19.7 oC	26.1 m3/h	0 m3/h
07:30:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	5.22 mg/L	19.7 oC	26.1 m3/h	0 m3/h
07:35:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	5.38 mg/L	19.8 oC	25.1 m3/h	0 m3/h

07:40:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	5.69 mg/L	19.8 oC	25.5 m3/h	0 m3/h
07:45:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	6.03 mg/L	19.7 oC	25.6 m3/h	0 m3/h
07:50:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	6.34 mg/L	19.7 oC	25.7 m3/h	0 m3/h
07:55:00	15/12/2025	7.7	10.8 mg/L	0.02 mg/L	6.53 mg/L	19.7 oC	25.6 m3/h	0 m3/h
08:00:00	15/12/2025	7.7	10.5 mg/L	0.03 mg/L	6.91 mg/L	19.7 oC	25.5 m3/h	0 m3/h
08:05:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	6.91 mg/L	19.7 oC	25.5 m3/h	0 m3/h
08:10:00	15/12/2025	7.7	10.8 mg/L	0.02 mg/L	7 mg/L	19.7 oC	25.3 m3/h	0 m3/h
08:15:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	6.94 mg/L	19.7 oC	25.4 m3/h	0 m3/h
08:20:00	15/12/2025	7.7	10.4 mg/L	0.02 mg/L	6.94 mg/L	19.8 oC	25.3 m3/h	0 m3/h
08:25:00	15/12/2025	7.7	10.8 mg/L	0.01 mg/L	6.72 mg/L	19.8 oC	25.3 m3/h	0 m3/h
08:30:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	6.56 mg/L	19.6 oC	25.3 m3/h	0 m3/h
08:35:00	15/12/2025	7.7	10.5 mg/L	0.01 mg/L	6.38 mg/L	19.6 oC	25.3 m3/h	0 m3/h
08:40:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	6.25 mg/L	19.7 oC	25.4 m3/h	0 m3/h
08:45:00	15/12/2025	7.7	10.4 mg/L	0.02 mg/L	6.06 mg/L	19.7 oC	25.4 m3/h	0 m3/h
08:50:00	15/12/2025	7.7	10.4 mg/L	0.02 mg/L	6 mg/L	19.9 oC	25.5 m3/h	0 m3/h
08:55:00	15/12/2025	7.7	10.5 mg/L	0.03 mg/L	5.84 mg/L	19.9 oC	25.5 m3/h	0 m3/h
09:00:00	15/12/2025	7.7	10.4 mg/L	0.02 mg/L	5.75 mg/L	20 oC	25.6 m3/h	0 m3/h
09:05:00	15/12/2025	7.7	10.4 mg/L	0.03 mg/L	5.34 mg/L	20 oC	25.6 m3/h	0 m3/h
09:10:00	15/12/2025	7.7	10.5 mg/L	0.03 mg/L	5.47 mg/L	20.2 oC	25.6 m3/h	0 m3/h
09:15:00	15/12/2025	7.7	10.4 mg/L	0.02 mg/L	5.59 mg/L	20.3 oC	25.6 m3/h	0 m3/h
09:20:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	5.5 mg/L	20.5 oC	25.6 m3/h	0 m3/h
09:25:00	15/12/2025	7.7	10.4 mg/L	0.01 mg/L	5.53 mg/L	20.6 oC	25.5 m3/h	0 m3/h
09:30:00	15/12/2025	7.7	10.3 mg/L	0.02 mg/L	5.63 mg/L	20.8 oC	25.5 m3/h	0 m3/h
09:35:00	15/12/2025	7.7	10.3 mg/L	0.01 mg/L	5.66 mg/L	20.9 oC	25.5 m3/h	0 m3/h
09:40:00	15/12/2025	7.7	10.2 mg/L	0.02 mg/L	5.84 mg/L	21.1 oC	26.2 m3/h	0 m3/h
09:45:00	15/12/2025	7.7	10.3 mg/L	0.01 mg/L	5.97 mg/L	21.1 oC	25.8 m3/h	0 m3/h
09:50:00	15/12/2025	7.7	10.1 mg/L	0.02 mg/L	6.16 mg/L	21.4 oC	25.5 m3/h	0 m3/h
09:55:00	15/12/2025	7.7	10.4 mg/L	0.02 mg/L	6.34 mg/L	21.5 oC	26.5 m3/h	0 m3/h
10:00:00	15/12/2025	7.7	10.1 mg/L	0.03 mg/L	6.63 mg/L	21.6 oC	25.5 m3/h	0 m3/h
10:05:00	15/12/2025	7.7	10.3 mg/L	0.03 mg/L	6.53 mg/L	22 oC	24.6 m3/h	0 m3/h
10:10:00	15/12/2025	7.7	10 mg/L	0.02 mg/L	7.16 mg/L	22 oC	28.7 m3/h	0 m3/h
10:15:00	15/12/2025	7.7	10.2 mg/L	0.02 mg/L	7.63 mg/L	22.2 oC	26.1 m3/h	0 m3/h
10:20:00	15/12/2025	7.7	9.99 mg/L	0.01 mg/L	7.91 mg/L	22.3 oC	26 m3/h	0 m3/h
10:25:00	15/12/2025	7.7	10 mg/L	0.02 mg/L	8.13 mg/L	22.6 oC	25.4 m3/h	0 m3/h
10:30:00	15/12/2025	7.7	10 mg/L	0.01 mg/L	8.69 mg/L	22.8 oC	26.7 m3/h	0 m3/h
10:35:00	15/12/2025	7.7	10.2 mg/L	0.02 mg/L	9.06 mg/L	23.1 oC	27.1 m3/h	0 m3/h
10:40:00	15/12/2025	7.7	10 mg/L	0.01 mg/L	9.44 mg/L	23.3 oC	25.6 m3/h	0 m3/h
10:45:00	15/12/2025	7.7	10.2 mg/L	0.02 mg/L	9.63 mg/L	23.6 oC	24.8 m3/h	0 m3/h
10:50:00	15/12/2025	7.7	10.2 mg/L	0.01 mg/L	10 mg/L	23.8 oC	26.1 m3/h	0 m3/h
10:55:00	15/12/2025	7.7	10.4 mg/L	0.02 mg/L	10 mg/L	24.1 oC	26.3 m3/h	0 m3/h
11:00:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	10.2 mg/L	24.3 oC	25.5 m3/h	0 m3/h
11:05:00	15/12/2025	7.7	10.7 mg/L	0.02 mg/L	10 mg/L	24.6 oC	23.2 m3/h	0 m3/h
11:10:00	15/12/2025	7.7	11.2 mg/L	0.03 mg/L	10.4 mg/L	24.8 oC	26.7 m3/h	0 m3/h

11:15:00	15/12/2025	7.7	9.59 mg/L	0.02 mg/L	10.7 mg/L	25.1 oC	23.9 m3/h	0 m3/h
11:20:00	15/12/2025	7.7	9.83 mg/L	0.03 mg/L	11 mg/L	25.3 oC	25.7 m3/h	0 m3/h
11:25:00	15/12/2025	7.7	10 mg/L	0.02 mg/L	11.3 mg/L	25.4 oC	25.1 m3/h	0 m3/h
11:30:00	15/12/2025	7.7	9.95 mg/L	0.02 mg/L	11.6 mg/L	25.7 oC	24.8 m3/h	0 m3/h
11:35:00	15/12/2025	7.8	10.3 mg/L	0.02 mg/L	11.8 mg/L	25.8 oC	0 m3/h	0 m3/h
11:40:00	15/12/2025	7.7	10.6 mg/L	0.02 mg/L	12.2 mg/L	25.9 oC	0 m3/h	0 m3/h
11:45:00	15/12/2025	7.7	11.6 mg/L	0.01 mg/L	12.4 mg/L	26.1 oC	0 m3/h	0 m3/h
11:50:00	15/12/2025	7.8	13.2 mg/L	0.03 mg/L	12.9 mg/L	26.2 oC	0 m3/h	0 m3/h
11:55:00	15/12/2025	7.8	15 mg/L	0.01 mg/L	13.3 mg/L	26.2 oC	0 m3/h	0 m3/h
12:00:00	15/12/2025	7.8	17.3 mg/L	0.02 mg/L	13.4 mg/L	26.3 oC	0 m3/h	0 m3/h
12:05:00	15/12/2025	7.8	20.3 mg/L	0.03 mg/L	13.4 mg/L	26.4 oC	0 m3/h	0 m3/h
12:10:00	15/12/2025	7.8	24.3 mg/L	0.01 mg/L	13.9 mg/L	26.6 oC	17 m3/h	0 m3/h
12:15:00	15/12/2025	7.8	9.56 mg/L	0.02 mg/L	14.3 mg/L	26.6 oC	27 m3/h	0 m3/h
12:20:00	15/12/2025	7.8	9.59 mg/L	0.02 mg/L	14.7 mg/L	26.6 oC	26.7 m3/h	0 m3/h
12:25:00	15/12/2025	7.8	9.51 mg/L	0.03 mg/L	14.9 mg/L	26.8 oC	26.5 m3/h	0 m3/h
12:30:00	15/12/2025	7.8	9.79 mg/L	0.01 mg/L	15.1 mg/L	26.9 oC	26.1 m3/h	0 m3/h
12:35:00	15/12/2025	7.8	10.1 mg/L	0.03 mg/L	15.4 mg/L	27 oC	25.7 m3/h	0 m3/h
12:40:00	15/12/2025	7.8	10.6 mg/L	0.02 mg/L	15.6 mg/L	26.9 oC	27 m3/h	0 m3/h
12:45:00	15/12/2025	7.8	10.9 mg/L	0.01 mg/L	15.7 mg/L	27.1 oC	26.5 m3/h	0 m3/h
12:50:00	15/12/2025	7.8	12.3 mg/L	0.02 mg/L	15.9 mg/L	27.2 oC	27.7 m3/h	0 m3/h
12:55:00	15/12/2025	7.8	14.1 mg/L	0.03 mg/L	16.3 mg/L	27.3 oC	27.6 m3/h	0 m3/h
13:00:00	15/12/2025	7.8	16.5 mg/L	0.02 mg/L	16.4 mg/L	27.3 oC	28.3 m3/h	0 m3/h
13:05:00	15/12/2025	7.8	18.9 mg/L	0.03 mg/L	16.1 mg/L	27.4 oC	27.9 m3/h	0 m3/h
13:10:00	15/12/2025	7.8	22 mg/L	0.02 mg/L	16.5 mg/L	27.6 oC	28.4 m3/h	0 m3/h
13:15:00	15/12/2025	7.8	9.36 mg/L	0.02 mg/L	16.9 mg/L	27.6 oC	26 m3/h	0 m3/h
13:20:00	15/12/2025	7.7	9.31 mg/L	0.02 mg/L	17.1 mg/L	27.6 oC	26.6 m3/h	0 m3/h
13:25:00	15/12/2025	7.8	9.59 mg/L	0.02 mg/L	17.3 mg/L	27.7 oC	26.6 m3/h	0 m3/h
13:30:00	15/12/2025	7.8	9.61 mg/L	0.02 mg/L	17.4 mg/L	27.7 oC	27.2 m3/h	0 m3/h
13:35:00	15/12/2025	7.8	9.56 mg/L	0.01 mg/L	17.8 mg/L	27.8 oC	27 m3/h	0 m3/h
13:40:00	15/12/2025	7.8	10 mg/L	0.03 mg/L	17.9 mg/L	27.8 oC	26.5 m3/h	0 m3/h
13:45:00	15/12/2025	7.8	10.9 mg/L	0.02 mg/L	18 mg/L	27.8 oC	25.7 m3/h	0 m3/h
13:50:00	15/12/2025	7.8	12.5 mg/L	0.01 mg/L	18.1 mg/L	27.9 oC	26 m3/h	0 m3/h
13:55:00	15/12/2025	7.8	15.6 mg/L	0.02 mg/L	18.5 mg/L	27.8 oC	25.9 m3/h	0 m3/h
14:00:00	15/12/2025	7.8	20.4 mg/L	0.02 mg/L	18.8 mg/L	27.7 oC	24.6 m3/h	0 m3/h
14:05:00	15/12/2025	7.8	29.4 mg/L	0.01 mg/L	18.8 mg/L	27.7 oC	25.3 m3/h	0 m3/h
14:10:00	15/12/2025	7.8	40.1 mg/L	0.02 mg/L	19.3 mg/L	27.7 oC	26.9 m3/h	0 m3/h
14:15:00	15/12/2025	7.8	9.26 mg/L	0.02 mg/L	19.5 mg/L	27.7 oC	27.4 m3/h	0 m3/h
14:20:00	15/12/2025	7.8	9.38 mg/L	0.02 mg/L	19.8 mg/L	27.7 oC	27.8 m3/h	0 m3/h
14:25:00	15/12/2025	7.8	9.63 mg/L	0.02 mg/L	19.9 mg/L	27.7 oC	25.8 m3/h	0 m3/h
14:30:00	15/12/2025	7.8	10.1 mg/L	0.03 mg/L	20.1 mg/L	27.7 oC	27 m3/h	0 m3/h
14:35:00	15/12/2025	7.8	11 mg/L	0.02 mg/L	20.3 mg/L	27.7 oC	27.2 m3/h	0 m3/h
14:40:00	15/12/2025	7.8	13.1 mg/L	0.02 mg/L	20.5 mg/L	27.7 oC	26.6 m3/h	0 m3/h
14:45:00	15/12/2025	7.8	16.9 mg/L	0.01 mg/L	20.5 mg/L	27.5 oC	27.6 m3/h	0 m3/h

14:50:00	15/12/2025	7.8	22.5 mg/L	0.01 mg/L	20.5 mg/L	27.6 oC	27.1 m3/h	0 m3/h
14:55:00	15/12/2025	7.8	30.4 mg/L	0.01 mg/L	20.8 mg/L	27.5 oC	27 m3/h	0 m3/h
15:00:00	15/12/2025	7.8	41.6 mg/L	0.02 mg/L	20.8 mg/L	27.5 oC	27.4 m3/h	0 m3/h
15:05:00	15/12/2025	7.8	38.2 mg/L	0.02 mg/L	20.8 mg/L	27.4 oC	26.5 m3/h	0 m3/h
15:10:00	15/12/2025	7.8	38 mg/L	0.02 mg/L	20.6 mg/L	27.4 oC	26.9 m3/h	0 m3/h
15:15:00	15/12/2025	7.8	9.83 mg/L	0.01 mg/L	20.3 mg/L	27.5 oC	27 m3/h	0 m3/h
15:20:00	15/12/2025	7.8	10.7 mg/L	0.02 mg/L	20 mg/L	27.3 oC	27.3 m3/h	0 m3/h
15:25:00	15/12/2025	7.8	12.3 mg/L	0.01 mg/L	19.5 mg/L	27.3 oC	27.6 m3/h	0 m3/h
15:30:00	15/12/2025	7.8	16.8 mg/L	0.01 mg/L	19.1 mg/L	27.2 oC	27.8 m3/h	0 m3/h
15:35:00	15/12/2025	7.8	21.4 mg/L	0.02 mg/L	18.8 mg/L	27.2 oC	27.9 m3/h	0 m3/h
15:40:00	15/12/2025	7.8	28.5 mg/L	0.03 mg/L	18.5 mg/L	27.1 oC	28.1 m3/h	0 m3/h
15:45:00	15/12/2025	7.8	35.8 mg/L	0.03 mg/L	18.1 mg/L	27.1 oC	28.2 m3/h	0 m3/h
15:50:00	15/12/2025	7.8	38 mg/L	0.02 mg/L	17.8 mg/L	27 oC	27.8 m3/h	0 m3/h
15:55:00	15/12/2025	7.8	38.2 mg/L	0.03 mg/L	17.5 mg/L	26.8 oC	27.7 m3/h	0 m3/h
16:00:00	15/12/2025	7.8	38.5 mg/L	0.01 mg/L	17 mg/L	26.8 oC	26.9 m3/h	0 m3/h
16:05:00	15/12/2025	7.8	38.2 mg/L	0.02 mg/L	16.9 mg/L	26.7 oC	24.5 m3/h	0 m3/h
16:10:00	15/12/2025	7.8	38.8 mg/L	0.02 mg/L	16.4 mg/L	26.5 oC	28.5 m3/h	0 m3/h
16:15:00	15/12/2025	7.8	9.49 mg/L	0.02 mg/L	15.9 mg/L	26.4 oC	26.9 m3/h	0 m3/h
16:20:00	15/12/2025	7.8	9.69 mg/L	0.01 mg/L	15.4 mg/L	26.3 oC	26.7 m3/h	0 m3/h
16:25:00	15/12/2025	7.8	10.8 mg/L	0.03 mg/L	14.9 mg/L	26.4 oC	26.1 m3/h	0 m3/h
16:30:00	15/12/2025	7.8	12.4 mg/L	0.02 mg/L	14.5 mg/L	26.1 oC	21.4 m3/h	0 m3/h
16:35:00	15/12/2025	7.8	13.2 mg/L	0.03 mg/L	14.1 mg/L	26 oC	19.2 m3/h	0 m3/h
16:40:00	15/12/2025	7.8	14.4 mg/L	0.02 mg/L	13.6 mg/L	26 oC	19.7 m3/h	0 m3/h
16:45:00	15/12/2025	7.8	14.7 mg/L	0.03 mg/L	13.3 mg/L	25.8 oC	27 m3/h	0 m3/h
16:50:00	15/12/2025	7.8	15 mg/L	0.02 mg/L	12.8 mg/L	25.7 oC	27 m3/h	0 m3/h
16:55:00	15/12/2025	7.8	18 mg/L	0.01 mg/L	12.4 mg/L	25.5 oC	27.1 m3/h	0 m3/h
17:00:00	15/12/2025	7.8	22 mg/L	0.01 mg/L	12 mg/L	25.4 oC	27 m3/h	0 m3/h
17:05:00	15/12/2025	7.8	23.2 mg/L	0.02 mg/L	11.8 mg/L	25.2 oC	28.7 m3/h	0 m3/h
17:10:00	15/12/2025	7.8	24.3 mg/L	0.02 mg/L	11.4 mg/L	25.1 oC	25.6 m3/h	0 m3/h
17:15:00	15/12/2025	7.8	9.76 mg/L	0.02 mg/L	10.8 mg/L	25.1 oC	26.8 m3/h	0 m3/h
17:20:00	15/12/2025	7.8	9.73 mg/L	0.01 mg/L	10.5 mg/L	24.8 oC	27.2 m3/h	0 m3/h
17:25:00	15/12/2025	7.8	9.79 mg/L	0.01 mg/L	10.1 mg/L	24.7 oC	27.1 m3/h	0 m3/h
17:30:00	15/12/2025	7.8	9.65 mg/L	0.02 mg/L	9.69 mg/L	24.6 oC	27.7 m3/h	0 m3/h
17:35:00	15/12/2025	7.8	9.82 mg/L	0.02 mg/L	9.38 mg/L	24.4 oC	28.2 m3/h	0 m3/h
17:40:00	15/12/2025	7.8	9.93 mg/L	0.02 mg/L	9.19 mg/L	24.2 oC	27.2 m3/h	0 m3/h
17:45:00	15/12/2025	7.8	10 mg/L	0.01 mg/L	8.88 mg/L	24.1 oC	27.6 m3/h	0 m3/h
17:50:00	15/12/2025	7.8	9.92 mg/L	0.02 mg/L	8.56 mg/L	23.9 oC	27.6 m3/h	0 m3/h
17:55:00	15/12/2025	7.8	10.1 mg/L	0.02 mg/L	8.38 mg/L	23.8 oC	28.1 m3/h	0 m3/h
18:00:00	15/12/2025	7.8	10.1 mg/L	0.02 mg/L	8.25 mg/L	23.7 oC	24.4 m3/h	0 m3/h
18:05:00	15/12/2025	7.8	9.96 mg/L	0.01 mg/L	8.25 mg/L	23.5 oC	21.7 m3/h	0 m3/h
18:10:00	15/12/2025	7.8	10 mg/L	0.01 mg/L	7.97 mg/L	23.4 oC	20.2 m3/h	0 m3/h
18:15:00	15/12/2025	7.8	9.83 mg/L	0.02 mg/L	7.63 mg/L	23.3 oC	25.7 m3/h	0 m3/h
18:20:00	15/12/2025	7.7	9.83 mg/L	0.02 mg/L	7.38 mg/L	23.2 oC	25.7 m3/h	0 m3/h

18:25:00	15/12/2025	7.7	10.1 mg/L	0.01 mg/L	7.28 mg/L	23.1 oC	25.5 m3/h	0 m3/h
18:30:00	15/12/2025	7.7	10.1 mg/L	0.02 mg/L	7.03 mg/L	22.9 oC	28.3 m3/h	0 m3/h
18:35:00	15/12/2025	7.7	10.1 mg/L	0.02 mg/L	7 mg/L	22.8 oC	27.4 m3/h	0 m3/h
18:40:00	15/12/2025	7.7	10 mg/L	0.01 mg/L	6.91 mg/L	22.7 oC	27.5 m3/h	0 m3/h
18:45:00	15/12/2025	7.7	10 mg/L	0.02 mg/L	7.03 mg/L	22.5 oC	27.5 m3/h	0 m3/h
18:50:00	15/12/2025	7.7	10 mg/L	0.01 mg/L	6.97 mg/L	22.4 oC	27.9 m3/h	0 m3/h
18:55:00	15/12/2025	7.7	10 mg/L	0.02 mg/L	6.84 mg/L	22.3 oC	28.1 m3/h	0 m3/h
19:00:00	15/12/2025	7.7	10.1 mg/L	0.01 mg/L	6.81 mg/L	22.3 oC	26.1 m3/h	0 m3/h
19:05:00	15/12/2025	7.7	10 mg/L	0.02 mg/L	6.81 mg/L	22.2 oC	25.5 m3/h	0 m3/h
19:10:00	15/12/2025	7.7	10.1 mg/L	0.03 mg/L	6.72 mg/L	22 oC	25.8 m3/h	0 m3/h
19:15:00	15/12/2025	7.7	10.1 mg/L	0.01 mg/L	6.53 mg/L	21.9 oC	35.6 m3/h	0 m3/h
19:20:00	15/12/2025	7.7	10.1 mg/L	0.02 mg/L	6.38 mg/L	21.8 oC	36.1 m3/h	0 m3/h
19:25:00	15/12/2025	7.7	10 mg/L	0.02 mg/L	6.38 mg/L	21.8 oC	36.3 m3/h	0 m3/h
19:30:00	15/12/2025	7.7	10.1 mg/L	0.01 mg/L	6.16 mg/L	21.6 oC	34.6 m3/h	0 m3/h
19:35:00	15/12/2025	7.7	10.1 mg/L	0.02 mg/L	6.16 mg/L	21.6 oC	41.5 m3/h	0 m3/h
19:40:00	15/12/2025	7.7	10.3 mg/L	0.03 mg/L	6.19 mg/L	21.5 oC	41.5 m3/h	0 m3/h
19:45:00	15/12/2025	7.7	10 mg/L	0.01 mg/L	6.13 mg/L	21.4 oC	41.4 m3/h	0 m3/h
19:50:00	15/12/2025	7.7	10.1 mg/L	0.02 mg/L	5.91 mg/L	21.3 oC	41.1 m3/h	0 m3/h
19:55:00	15/12/2025	7.7	10.1 mg/L	0.01 mg/L	5.88 mg/L	21.3 oC	41.1 m3/h	0 m3/h
20:00:00	15/12/2025	7.7	10.4 mg/L	0.02 mg/L	5.88 mg/L	21.1 oC	40.4 m3/h	0 m3/h
20:05:00	15/12/2025	7.7	10.4 mg/L	0.02 mg/L	5.84 mg/L	21.1 oC	44.3 m3/h	0 m3/h
20:10:00	15/12/2025	7.7	10.2 mg/L	0.01 mg/L	5.97 mg/L	21.1 oC	43.8 m3/h	0 m3/h
20:15:00	15/12/2025	7.7	10.2 mg/L	0.01 mg/L	5.84 mg/L	21.1 oC	43.6 m3/h	0 m3/h
20:20:00	15/12/2025	7.7	10.3 mg/L	0.01 mg/L	5.81 mg/L	20.9 oC	45 m3/h	0 m3/h
20:25:00	15/12/2025	7.7	10.2 mg/L	0.02 mg/L	5.69 mg/L	20.9 oC	44.2 m3/h	0 m3/h
20:30:00	15/12/2025	7.7	10.2 mg/L	0.01 mg/L	5.59 mg/L	20.8 oC	43.8 m3/h	0 m3/h
20:35:00	15/12/2025	7.7	10.3 mg/L	0.02 mg/L	5.5 mg/L	20.9 oC	43.4 m3/h	0 m3/h
20:40:00	15/12/2025	7.7	10.3 mg/L	0.03 mg/L	5.59 mg/L	20.7 oC	42.9 m3/h	0 m3/h
20:45:00	15/12/2025	7.7	10.1 mg/L	0.02 mg/L	5.44 mg/L	20.7 oC	43 m3/h	0 m3/h
20:50:00	15/12/2025	7.7	10.2 mg/L	0.02 mg/L	5.41 mg/L	20.6 oC	42.9 m3/h	0 m3/h
20:55:00	15/12/2025	7.7	10.1 mg/L	0.01 mg/L	5.34 mg/L	20.5 oC	42.4 m3/h	0 m3/h
21:00:00	15/12/2025	7.7	10.3 mg/L	0.02 mg/L	5.31 mg/L	20.5 oC	42.5 m3/h	0 m3/h
21:05:00	15/12/2025	7.7	10.3 mg/L	0.02 mg/L	5.34 mg/L	20.4 oC	42.4 m3/h	0 m3/h
21:10:00	15/12/2025	7.7	10 mg/L	0.02 mg/L	5.56 mg/L	20.4 oC	42.1 m3/h	0 m3/h
21:15:00	15/12/2025	7.7	10.1 mg/L	0.02 mg/L	5.47 mg/L	20.3 oC	42.3 m3/h	0 m3/h
21:20:00	15/12/2025	7.7	10.2 mg/L	0.02 mg/L	5.41 mg/L	20.3 oC	42.2 m3/h	0 m3/h
21:25:00	15/12/2025	7.7	10.3 mg/L	0.01 mg/L	5.31 mg/L	20.3 oC	42 m3/h	0 m3/h
21:30:00	15/12/2025	7.7	10.2 mg/L	0.02 mg/L	5.31 mg/L	20.3 oC	42.4 m3/h	0 m3/h
21:35:00	15/12/2025	7.7	10.2 mg/L	0.03 mg/L	5.28 mg/L	20.2 oC	42.1 m3/h	0 m3/h
21:40:00	15/12/2025	7.7	10.2 mg/L	0.02 mg/L	5.28 mg/L	20.2 oC	42.2 m3/h	0 m3/h
21:45:00	15/12/2025	7.7	10.2 mg/L	0.01 mg/L	5.34 mg/L	20.1 oC	42.5 m3/h	0 m3/h
21:50:00	15/12/2025	7.7	10.1 mg/L	0.03 mg/L	5.34 mg/L	20.1 oC	42.7 m3/h	0 m3/h
21:55:00	15/12/2025	7.7	10.2 mg/L	0.01 mg/L	5.31 mg/L	20 oC	42.5 m3/h	0 m3/h

22:00:00	15/12/2025	7.7	10.3 mg/L	0.01 mg/L	5.31 mg/L	20 oC	42.2 m3/h	0 m3/h
22:05:00	15/12/2025	7.7	10.2 mg/L	0.02 mg/L	5.31 mg/L	20.1 oC	42.1 m3/h	0 m3/h
22:10:00	15/12/2025	7.7	10.1 mg/L	0.01 mg/L	5.5 mg/L	20.1 oC	42.2 m3/h	0 m3/h
22:15:00	15/12/2025	7.7	10.3 mg/L	0.03 mg/L	5.31 mg/L	20 oC	42.5 m3/h	0 m3/h
22:20:00	15/12/2025	7.7	10.2 mg/L	0.03 mg/L	5.28 mg/L	19.9 oC	43.6 m3/h	0 m3/h
22:25:00	15/12/2025	7.7	10.3 mg/L	0.03 mg/L	5.22 mg/L	19.9 oC	42.8 m3/h	0 m3/h
22:30:00	15/12/2025	7.7	10.2 mg/L	0.02 mg/L	5.19 mg/L	20 oC	42.4 m3/h	0 m3/h
22:35:00	15/12/2025	7.7	10.3 mg/L	0.02 mg/L	5.19 mg/L	19.9 oC	41 m3/h	0 m3/h
22:40:00	15/12/2025	7.7	10.4 mg/L	0.02 mg/L	5.19 mg/L	19.8 oC	37.3 m3/h	0 m3/h
22:45:00	15/12/2025	7.7	10.4 mg/L	0.02 mg/L	5.25 mg/L	19.8 oC	41 m3/h	0 m3/h
22:50:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	5.22 mg/L	19.8 oC	38.7 m3/h	0 m3/h
22:55:00	15/12/2025	7.7	10.1 mg/L	0.02 mg/L	5.22 mg/L	19.8 oC	37 m3/h	0 m3/h
23:00:00	15/12/2025	7.7	10.3 mg/L	0.03 mg/L	5.34 mg/L	19.9 oC	36.5 m3/h	0 m3/h
23:05:00	15/12/2025	7.7	10.2 mg/L	0.02 mg/L	5.44 mg/L	19.8 oC	33 m3/h	0 m3/h
23:10:00	15/12/2025	7.7	10.2 mg/L	0.02 mg/L	5.78 mg/L	19.7 oC	33.9 m3/h	0 m3/h
23:15:00	15/12/2025	7.7	10.5 mg/L	0.02 mg/L	5.84 mg/L	19.7 oC	33.6 m3/h	0 m3/h
23:20:00	15/12/2025	7.7	10.3 mg/L	0.01 mg/L	5.88 mg/L	19.7 oC	31.3 m3/h	0 m3/h
23:25:00	15/12/2025	7.7	10.2 mg/L	0.03 mg/L	6.13 mg/L	19.6 oC	29.5 m3/h	0 m3/h
23:30:00	15/12/2025	7.7	10.2 mg/L	0.03 mg/L	6.22 mg/L	19.7 oC	0 m3/h	0 m3/h
23:35:00	15/12/2025	7.7	10.2 mg/L	0.01 mg/L	6.34 mg/L	19.7 oC	0 m3/h	0 m3/h
23:40:00	15/12/2025	7.7	10 mg/L	0.02 mg/L	6.72 mg/L	19.9 oC	0 m3/h	0 m3/h
23:45:00	15/12/2025	7.7	10.3 mg/L	0.01 mg/L	6.88 mg/L	19.8 oC	0 m3/h	0 m3/h
23:50:00	15/12/2025	7.7	10.1 mg/L	0.02 mg/L	7.09 mg/L	19.8 oC	0 m3/h	0 m3/h
23:55:00	15/12/2025	7.7	10.3 mg/L	0.01 mg/L	7.41 mg/L	19.8 oC	0 m3/h	0 m3/h
00:00:00	16/12/2025	7.7	10.2 mg/L	0.02 mg/L	7.69 mg/L	19.8 oC	0 m3/h	0 m3/h
00:05:00	16/12/2025	7.7	10.2 mg/L	0.01 mg/L	7.78 mg/L	19.9 oC	0 m3/h	0 m3/h
00:10:00	16/12/2025	7.7	10.2 mg/L	0.01 mg/L	8.13 mg/L	19.8 oC	0 m3/h	0 m3/h
00:15:00	16/12/2025	7.7	10.3 mg/L	0.01 mg/L	8.19 mg/L	19.8 oC	0 m3/h	0 m3/h
00:20:00	16/12/2025	7.7	10.2 mg/L	0.02 mg/L	8.38 mg/L	19.8 oC	0 m3/h	0 m3/h
00:25:00	16/12/2025	7.7	10.4 mg/L	0.02 mg/L	8.63 mg/L	19.8 oC	0 m3/h	0 m3/h
00:30:00	16/12/2025	7.7	10.2 mg/L	0.02 mg/L	8.63 mg/L	19.8 oC	0 m3/h	0 m3/h
00:35:00	16/12/2025	7.7	10.3 mg/L	0.02 mg/L	8.75 mg/L	19.8 oC	0 m3/h	0 m3/h
00:40:00	16/12/2025	7.7	10.3 mg/L	0.03 mg/L	8.81 mg/L	19.8 oC	0 m3/h	0 m3/h
00:45:00	16/12/2025	7.7	10.3 mg/L	0.01 mg/L	8.94 mg/L	19.8 oC	0 m3/h	0 m3/h
00:50:00	16/12/2025	7.7	10.2 mg/L	0.03 mg/L	9 mg/L	19.8 oC	0 m3/h	0 m3/h
00:55:00	16/12/2025	7.7	10.5 mg/L	0.02 mg/L	9.25 mg/L	19.8 oC	0 m3/h	0 m3/h
01:00:00	16/12/2025	7.7	10.2 mg/L	0.03 mg/L	9.13 mg/L	19.8 oC	0 m3/h	0 m3/h